

By Speed Post

F.No. CP-11/40/2021-IPC-III-HO-CPCB-HO/ 3565

July 16, 2021

To,

M/s Vardhman Polytex Limited,
295/1, Phase 8, Focal Point,
Ludhiana, Punjab

Sub: Inspection of M/s Vardhman Polytex Limited, 295/1, Phase 8, Focal Point, Ludhiana, Punjab-Regd.

Sir,

It is to inform you that M/s Vardhman Polytex Limited, 295/1, Phase 8, Focal Point, Ludhiana, Punjab was inspected by a team of CPCB officials on 23.06.2021 to verify the compliance status of the industries under the special drive in catchment of River Sutlej within the jurisdiction of Punjab. The Unit was found generally complying with the effluent discharge. Based on the observations made by the inspection team, the following recommendations are required to be complied by the unit:

1. The unit shall properly operate its ETP and maintain desired MLSS in Aeration Tank.
2. The unit shall obtain NOC from CGWA.
3. The unit shall provide proper leachate collection system at Sludge Drying Beds.
4. The unit shall provide proper equalization system at Equalization tank
5. The unit shall ensure to comply with the provision of disposal of HW as per the Hazardous and Other Waste (M&TM) Rules, 2016.

In this context, it is requested to ensure compliance of the aforesaid recommendations of the inspection team and terms & conditions of the consent to operate granted by Punjab PCB and submit ATR to CPCB at the earliest.

This issues with the approval of the Member Secretary, CPCB.

Yours faithfully,




(P.K. Mishra)
Additional Director &
Divisional Head- IPC-III

o/c

Copy to:

1. **The Member Secretary,** : With a request to keep this under surveillance for ensuring complete & continuous compliance of stipulated norms & terms & conditions of consent order
Punjab Pollution Control Board
(PPCB), Vatavaran Bhawan, Nabha
Road, Patiala - 147 001
2. **The Regional Director,** : For follow-up action please.
Regional Directorate, CPCB
Second Floor, Telephone Exchange,
Sector 49, Chandigarh - 160047



16/07/21
(P.K. Mishra)

o/c

NS/29
20/07/21