

SPEED POST

B-33014/07/2017-18/IPC-II/TPP/

December 11, 2017

To

The General Manager  
Rajiv Gandhi Thermal Power Project (RGTPP),  
Khedar, Hisar, Haryana

Sub: Directions under Section 5 of the Environment (Protection) Act, 1986 regarding compliance of emission limit notified vide notification No.S.O.3305 (E) dated 07.12.2015 - reg.

WHEREAS, taking into consideration pollution from thermal power plants, Ministry of Environment, Forest & Climate Change had issued notification in the year 1984 laying out standards for thermal power plants. Further, the stack height regulation was notified in the year 1989 and effluent standard for thermal power plants was notified in the year 1986. The revised temperature limit of discharge of cooling water from the plants was notified in the year 1999 and thereafter use of beneficiated coal in the plants was issued in June 2002. The fly ash utilization notification was also issued On 14th September, 1999 and amended in the year 2003 and 2009. Thereafter, MoEF&CC vide Notification No. S.O.3305(E) dated 07.12.2015 has amended emission limit for particulate matter and notified new limits for Sulphur dioxide (SO<sub>2</sub>), Oxides of Nitrogen (NO<sub>x</sub>) and mercury emission, and water consumption limit for coal/lignite based thermal power plants. As per the notification dated 07.12.2015, thermal power plants are required to achieve the notified limit within two years from the date of the notification i.e. by 07.12.2017;

WHEREAS, with the implementation of the amendment dated 07.12.2015, it is expected that there would be reduction in emission of PM, Sulphur dioxide and oxide of Nitrogen, which in turn will help in improvement in Ambient Air Quality in and around thermal power plants, besides reduction of mercury emission and water use in the thermal power plants will reduce;

WHEREAS, in the meeting on Coal Washeries (Environment & Forest Clearances) and Emission Norms for Thermal Power Plants chaired by the Hon'ble Minister of Environment, Forest & Climate Change and Minister of Power, Coal & Renewable Energy on June 08, 2016, it was decided that a committee comprising representatives from MoEF & CC, Ministry of Power (MoP), Central electricity Authority (CEA), Ministry of Coal (MoC), Power Grid Corporation of India Limited (PGCI) and Central Pollution Control Board (CPCB) may be constituted to look into the all issues related to implementation of norms;

WHEREAS, following decisions were taken in the meeting:

1. MoP/CEA shall submit action plan by December 2016 for phasing out of the power plants commissioned before December, 2003.
2. MoP / CEA shall submit action plan by December, 2016 in respect of power plants commissioned during January, 2004 to December, 2016 indicating unit wise retrofit / renovation for each power plant. The implementation of action plan shall be taken up in backward manner starting from the plants commissioned in the 2015 and the shall be completed by 15.08.2022
3. MoP and CEA shall coordinate with each State Public Sector Undertakings separately for submission of action plan by December, 2016 for all the power plants.

WHEREAS, it was further decided that MoP shall take action for installation of Flue gas Desulphurisation (FGD) if needed to achieve prescribed SO<sub>2</sub> norms based on the SO<sub>2</sub> emission levels from power plants;

WHEREAS, it was also pointed out that NO<sub>x</sub> control technology in case of Indian coal is not established. Selective Catalytic Reduction (SCR) technology is used for NO<sub>x</sub> control, however, its feasibility for Indian coal needs to be established. MoP suggested that Pilot studies may be taken up in two plants and based on the results, further action plan to be drawn regarding retrofitting of SCR in plants to achieve prescribed NO<sub>x</sub> norms;

WHEREAS, the MoP constituted a committee under the Chairmanship of Chairman, Central Electricity Authority (CEA) on 21.09.2016 to prepare an action plan for implementation of new emission limits;

WHEREAS, to ensure compliance of the new emission norms the MOEF&CC convened a meeting on 23.05.2017 in which CEA, NTPC and the Central Pollution Control Board participated;

WHEREAS, the MOEF&CC received a letter from Secretary Ministry of Power *vide* their D.O. letter No. FU-1/2016-IPC dated 30<sup>th</sup> June, 2017 indicating the concerns of various thermal power plants in the country with regard to the compliance with the new emission norms for the thermal power plants notified on 7.12.2015 particularly w.r.t. Particulate Matter (PM), Sulphur dioxide (SO<sub>2</sub>) & Oxides of Nitrogen (NO<sub>x</sub>);

WHEREAS, it was noted that out of present 196667 MW installed capacity, about 60 % capacity (1,15,214 MW) meets the new PM norms with existing ESP installations. Remaining capacity of 64,334 MW which does not meet the new environmental norms regarding PM, requiring retrofitting additional fields in Electrostatic Precipitator (ESP)/replacement of ESP in existing plants to meet the new emission norms of PM;

WHEREAS, Ministry of Power after consultation with Central electricity Authority informed that retrofitting additional fields in

ESP/replacement of ESP in existing plants will need complete shutdown of 4-6 months for each unit;

WHEREAS, in order to meet SO<sub>2</sub> emission norms, FGD system shall be required to be installed in all plants. MoP informed that about 30-36 months required for design & engineering, approvals, funds arrangements, tendering, erection and commissioning of FGD. Besides, planned shutdown will be required as all plants cannot be shut down simultaneously. Another challenge highlighted for installation of FGD was availability of technologies/suppliers. In addition, issues relating to availability of good quality lime stone for operation of FGD and disposal of Gypsum to run the FGD in existing plants were also taken note of;

WHEREAS, the standard of 300 & 100 mg/NM<sup>3</sup> would require installation of Selective Non Catalytic Reduction (SNCR) or Selective Non Catalytic Reduction (SCR). While these technologies are established globally, these are not established for Indian Coal, which has high ash content. Therefore, it was decided to engage various technology vendors to run pilots at NTPC stations to validate technology of SNCR/SCR system for Indian coal;

WHEREAS, the Ministry of Power in the letter dated 30.06.2017 enclosed the report outlining the plan of action for implementation of the new norms keeping in mind the techno-economic feasibility and ensuring availability of power to all at affordable cost without any disruption;

WHEREAS, as per the phasing plan proposed by MOP after consultation with CEA and Regional Power Committees, out of the installed capacity of 1, 87,162 MW ( as on December, 2016), 8217 MW have been identified for retirement/already retired. Further, 12,974 MW of capacity already have either CFBC boilers or FGDs.

WHEREAS, a phasing plan was proposed for the balance 165971 MW of coal based thermal capacity for achieving compliance with 145977 MW capacity proposing installation of FGDs within a period of 7 years to be undertaken in a phased manner. About 3205 MW of coal based capacity was stated to be compliant with revised norms of SO<sub>2</sub> emission;

WHEREAS, it was further noted that approximately about 16789 MW would not be able to install FGDs due to various constraints which include lack of space, etc.;

WHEREAS, CEA has worked out the requirement of capacity of coal based thermal power plants including hydro, wind, solar, gas based units to meet the estimated peak demand of 225 GW in 2021-22;

WHEREAS, MoP suggested that the compliance period of PM for the plants installing FGD may be kept same as per the FGD phasing plan;

WHEREAS, it was requested that for implementation of NO<sub>x</sub> norms in the plants installed before 31.12.2003 a period of three years may be permitted to achieve specified standards of 600 mg/Nm<sup>3</sup>. For other plants a relaxation of 600 mg/Nm<sup>3</sup> in place of 300 and 100 mg/Nm<sup>3</sup> for a period of 3 years was also requested;

WHEREAS, taking into account the issues/concerns raised by the MoP and the sensitivity involved in the matter as it relates to general public of the country, the Ministry undertook detailed analysis of each of the issues in the meetings held on 06.07.2017, 27.07.2017, 11.08.2017 and 01.09.2017. These meetings were also attended by the various stakeholders including Ministry of Power, CEA, NTPC etc.;

WHEREAS, MOEF & CC in the meeting with MoP, CEA, NTPC & CPCB etc. held on September 1, 2017 decided that the action plan submitted by MoP for 7 years i.e. up to 2024 was too long and it should instead commence from 2018 and implemented by 2022 with respect to all pollutants. It was further suggested that action plan should be revised prioritising the plants located in critically polluted area /close to habitation /urban area. Based on the decisions taken in the meeting Ministry of Power vide letter No. FU-1/2017-IPC dated 13.10.2017 submitted the revised action plan, to implement/phasing FGD installation/ ESP upgradation to meet new emission norms for thermal power plants;

WHEREAS, as per the revised plan submitted by the MoP vide letter dated 13.10.2017, 650 units comprising 196667 MW need to meet the new emission limits. Out of 650 units, FGD will be installed to achieve the emission limit of SO<sub>2</sub> by the year 2022 in all 415 units comprising 161522 MW (01 unit by 2018, 08 units by 2019, and 55 units by 2020, 172 units by 2021 and 178 units by 2022, for 01 units with 150 MW capacity plan is not received). Remaining 235 units comprised of 35145 MW either complying with SO<sub>2</sub> emission limits or planned for phasing out;

WHEREAS, ESP upgradation to achieve emission limit of particulate matter will be completed by the year 2022 in PM for 231 units comprising of 65925 MW capacity out of 650 units (01 unit by 2018, 02 units by 2019, 28 units by 2020, 97 units by 2021 and 94 units by 2022, for 09 units of 1400 MW capacity plan by 2022);

WHEREAS, with regard to compliance of emission limit of NO<sub>x</sub>, it is suggested that pre combustion modification such as in situ modification in boiler, installation of Low NO<sub>x</sub> burners and Over Fire Air shall be adopted besides installation of SCR/SNCR systems wherever needed by the year 2022;

WHEREAS, electricity is cleanest form of energy which helps in mitigating house hold air pollution which is matter of concern;

WHEREAS, there is need to provide electricity supply to people who do not yet have access to it;



WHEREAS, taking into consideration the technical challenges and time requirements for installation of FGD and other technologies to meet the new emission limits, the MoEF&CC vide its letter F. No. Q-15017/40/2007-CPW dated 07.12.2017 has directed CPCB to direct all the thermal power plants to ensure compliance with the norms laid down in the 07.12.2015 notification in accordance with the revised Plan submitted by the Ministry of Power letter dated 13.10.2017 as well as NOx by 2022;

WHEREAS, the Ministry of Environment, Forest & Climate Change, Government of India, vide Notifications No. S. O. 157 (E) of 27.02.1996 and S. O. 730 (E) dated 10.07.2002, has delegated the powers vested under Section 5 of the Environment (Protection) Act, 1986 (29 of 1986) to the Chairman, Central Pollution Control Board, to issue directions to any industry or any local body or any other authority for violations of the standards and rules notified under the Environment (Protection) Rules, 1986 and amendment thereof.

NOW, THEREFORE, taking into consideration all material facts including environmental concerns and ensuring stability of power supply and need for phasing the implementation, in exercise of powers vested under Section 5 of the Environment (Protection) Act, 1986, following directions are issued to M/s Rajeev Gandhi Thermal Power Station, Hisar, HPGCL:

- i. That plant shall install/retrofit Electrostatic Precipitator (ESP) by December 31, 2019 in unit 1 & 2 respectively so as to achieve PM emission limit.
- ii. That plant shall install FGD by December 31, 2019 in Unit 1 & 2 respectively so as to comply SO<sub>2</sub> emission limit
- iii. That plant shall take immediate measure like installation of low NOx burners, providing Over Fire Air (OFA) etc. and achieve progressive reduction so as to comply NOx emission limit by the year 2019

The time line mentioned above (i to iii) for compliance of PM, SO<sub>2</sub> & NOx emission limits shall be reviewed by CPCB within a period of three months and shall be brought down further considering the location specificity of the plant such as critical polluted area/ closeness to habitation/ urban area.

The time line for compliance of water consumption limit shall also be finalised in consultation of plants


M/s Rajeev Gandhi Thermal Power Station, Hisar, HPGCL shall ensure compliance of directions mentioned above (i to iii) failing which action will be taken under the appropriate provisions of the Environment (Protection) Act, 1986.

(A.K. Mehta)  
Chairman



Copy to:

1. The Chairman  
Haryana State Pollution Control Board  
C-11, Sector-6, Panchkula- 134 109,  
Haryana
2. The Joint Secretary (CP Division)  
Ministry of Environment, Forests and Climate Change  
Prithvi Wing, 2nd Floor, Room No. 216  
Indira Paryavaran Bhawan, Aliganj,  
Jor Bagh Road, New Delhi - 110 003
3. The Joint Secretary (Thermal)  
Ministry of Power  
Shram Shakti Bhawan, Rafi Marg  
New Delhi
4. The Regional Director,  
Central Pollution Control Board  
PICUP Bhawan, Ground Floor  
Vibhuti Khand, Gomti Nagar  
Lucknow-226010
5. The Divisional Head - IT, CPCB

  
(A. Sudhakar)  
Member Secretary

SPEED POST

B-33014/07/2017-18/IPC-II/TPP/

December 11, 2017

To

The General Manager  
Tenughat Thermal Power Station  
Tenughat Valley Corporation  
Dist: Tenughat, Jharkhand

**Sub: Directions under Section 5 of the Environment (Protection) Act, 1986 regarding compliance of emission limit notified vide notification No.S.O.3305 (E) dated 07.12.2015 - reg.**

WHEREAS, taking into consideration pollution from thermal power plants, Ministry of Environment, Forest & Climate Change had issued notification in the year 1984 laying out standards for thermal power plants. Further, the stack height regulation was notified in the year 1989 and effluent standard for thermal power plants was notified in the year 1986. The revised temperature limit of discharge of cooling water from the plants was notified in the year 1999 and thereafter use of beneficiated coal in the plants was issued in June 2002. The fly ash utilization notification was also issued On 14th September, 1999 and amended in the year 2003 and 2009. Thereafter, MoEF&CC vide Notification No. S.O.3305(E) dated 07.12.2015 has amended emission limit for particulate matter and notified new limits for Sulphur dioxide (SO<sub>2</sub>), Oxides of Nitrogen (NO<sub>x</sub>) and mercury emission, and water consumption limit for coal/lignite based thermal power plants. As per the notification dated 07.12.2015, thermal power plants are required to achieve the notified limit within two years from the date of the notification i.e. by 07.12.2017;

WHEREAS, with the implementation of the amendment dated 07.12.2015, it is expected that there would be reduction in emission of PM, Sulphur dioxide and oxide of Nitrogen, which in turn will help in improvement in Ambient Air Quality in and around thermal power plants, besides reduction of mercury emission and water use in the thermal power plants will reduce;

WHEREAS, in the meeting on Coal Washeries (Environment & Forest Clearances) and Emission Norms for Thermal Power Plants chaired by the Hon'ble Minister of Environment, Forest & Climate Change and Minister of Power, Coal & Renewable Energy on June 08, 2016, it was decided that a committee comprising representatives from MoEF & CC, Ministry of Power (MoP), Central electricity Authority (CEA), Ministry of Coal (MoC), Power Grid Corporation of India Limited (PGCI) and Central Pollution Control Board (CPCB) may be constituted to look into the all issues related to implementation of norms;

WHEREAS, following decisions were taken in the meeting:

1. MoP/CEA shall submit action plan by December 2016 for phasing out of the power plants commissioned before December, 2003.
2. MoP / CEA shall submit action plan by December, 2016 in respect of power plants commissioned during January, 2004 to December, 2016 indicating unit wise retrofit / renovation for each power plant. The implementation of action plan shall be taken up in backward manner starting from the plants commissioned in the 2015 and the shall be completed by 15.08.2022
3. MoP and CEA shall coordinate with each State Public Sector Undertakings separately for submission of action plan by December, 2016 for all the power plants.

WHEREAS, it was further decided that MoP shall take action for installation of Flue gas Desulphurisation (FGD) if needed to achieve prescribed SO<sub>2</sub> norms based on the SO<sub>2</sub> emission levels from power plants;

WHEREAS, it was also pointed out that NO<sub>x</sub> control technology in case of Indian coal is not established. Selective Catalytic Reduction (SCR) technology is used for NO<sub>x</sub> control, however, its feasibility for Indian coal needs to be established. MoP suggested that Pilot studies may be taken up in two plants and based on the results, further action plan to be drawn regarding retrofitting of SCR in plants to achieve prescribed NO<sub>x</sub> norms;

WHEREAS, the MoP constituted a committee under the Chairmanship of Chairman, Central Electricity Authority (CEA) on 21.09.2016 to prepare an action plan for implementation of new emission limits;

WHEREAS, to ensure compliance of the new emission norms the MOEF&CC convened a meeting on 23.05.2017 in which CEA, NTPC and the Central Pollution Control Board participated;

WHEREAS, the MOEF&CC received a letter from Secretary Ministry of Power *vide* their D.O. letter No. FU-1/2016-IPC dated 30<sup>th</sup> June, 2017 indicating the concerns of various thermal power plants in the country with regard to the compliance with the new emission norms for the thermal power plants notified on 7.12.2015 particularly w.r.t. Particulate Matter (PM), Sulphur dioxide (SO<sub>2</sub>) & Oxides of Nitrogen (NO<sub>x</sub>);

WHEREAS, it was noted that out of present 196667 MW installed capacity, about 60 % capacity (1,15,214 MW) meets the new PM norms with existing ESP installations. Remaining capacity of 64,334 MW which does not meet the new environmental norms regarding PM, requiring retrofitting additional fields in Electrostatic Precipitator (ESP)/replacement of ESP in existing plants to meet the new emission norms of PM;

WHEREAS, Ministry of Power after consultation with Central electricity Authority informed that retrofitting additional fields in ESP/replacement of ESP in existing plants will need complete shutdown of 4-6 months for each unit;

WHEREAS, in order to meet SO<sub>2</sub> emission norms, FGD system shall be required to be installed in all plants. MoP informed that about 30-36 months required for design & engineering, approvals, funds arrangements, tendering, erection and commissioning of FGD. Besides, planned shutdown will be required as all plants cannot be shut down simultaneously. Another challenge highlighted for installation of FGD was availability of technologies/suppliers. In addition, issues relating to availability of good quality lime stone for operation of FGD and disposal of Gypsum to run the FGD in existing plants were also taken note of;

WHEREAS, the standard of 300 & 100 mg/NM<sup>3</sup> would require installation of Selective Non Catalytic Reduction (SNCR) or Selective Non Catalytic Reduction (SCR). While these technologies are established globally, these are not established for Indian Coal, which has high ash content. Therefore, it was decided to engage various technology vendors to run pilots at NTPC stations to validate technology of SNCR/SCR system for Indian coal;

WHEREAS, the Ministry of Power in the letter dated 30.06.2017 enclosed the report outlining the plan of action for implementation of the new norms keeping in mind the techno-economic feasibility and ensuring availability of power to all at affordable cost without any disruption;

WHEREAS, as per the phasing plan proposed by MOP after consultation with CEA and Regional Power Committees, out of the installed capacity of 1, 87,162 MW ( as on December, 2016), 8217 MW have been identified for retirement/already retired. Further, 12,974 MW of capacity already have either CFBC boilers or FGDs.

WHEREAS, a phasing plan was proposed for the balance 165971 MW of coal based thermal capacity for achieving compliance with 145977 MW capacity proposing installation of FGDs within a period of 7 years to be undertaken in a phased manner. About 3205 MW of coal based capacity was stated to be compliant with revised norms of SO<sub>2</sub> emission; ...

WHEREAS, it was further noted that approximately about 16789 MW would not be able to install FGDs due to various constraints which include lack of space, etc.;

WHEREAS, CEA has worked out the requirement of capacity of coal based thermal power plants including hydro, wind, solar, gas based units to meet the estimated peak demand of 225 GW in 2021-22;

WHEREAS, MoP suggested that the compliance period of PM for the plants installing FGD may be kept same as per the FGD phasing plan;



WHEREAS, it was requested that for implementation of NO<sub>x</sub> norms in the plants installed before 31.12.2003 a period of three years may be permitted to achieve specified standards of 600 mg/Nm<sup>3</sup>. For other plants a relaxation of 600 mg/Nm<sup>3</sup> in place of 300 and 100 mg/Nm<sup>3</sup> for a period of 3 years was also requested;

WHEREAS, taking into account the issues/concerns raised by the MoP and the sensitivity involved in the matter as it relates to general public of the country, the Ministry undertook detailed analysis of each of the issues in the meetings held on 06.07.2017, 27.07.2017, 11.08.2017 and 01.09.2017. These meetings were also attended by the various stakeholders including Ministry of Power, CEA, NTPC etc.;

WHEREAS, MOEF & CC in the meeting with MoP, CEA, NTPC & CPCB etc. held on September 1, 2017 decided that the action plan submitted by MoP for 7 years i.e. up to 2024 was too long and it should instead commence from 2018 and implemented by 2022 with respect to all pollutants. It was further suggested that action plan should be revised prioritising the plants located in critically polluted area /close to habitation /urban area. Based on the decisions taken in the meeting Ministry of Power vide letter No. FU-1/2017-IPC dated 13.10.2017 submitted the revised action plan, to implement/phasing FGD installation/ ESP upgradation to meet new emission norms for thermal power plants;

WHEREAS, as per the revised plan submitted by the MoP vide letter dated 13.10.17, 650 units comprising 196667 MW need to meet the new emission limits. Out of 650 units, FGD will be installed to achieve the emission limit of SO<sub>2</sub> by the year 2022 in all 415 units comprising 161522 MW (01 unit by 2018, 08 units by 2019, and 55 units by 2020, 172 units by 2021 and 178 units by 2022, for 01 units with 150 MW capacity plan is not received). Remaining 235 units comprised of 35145 MW either complying with SO<sub>2</sub> emission limits or planned for phasing out;

WHEREAS, ESP upgradation to achieve emission limit of particulate matter will be completed by the year 2022 in PM for 231 units comprising of 65925 MW capacity out of 650 units (01 unit by 2018, 02 units by 2019, 28 units by 2020, 97 units by 2021 and 94 units by 2022, for 09 units of 1400 MW capacity plan by 2022);

WHEREAS, with regard to compliance of emission limit of NO<sub>x</sub>, it is suggested that pre combustion modification such as in situ modification in boiler, installation of Low NO<sub>x</sub> burners and Over Fire Air shall be adopted besides installation of SCR/SNCR systems wherever needed by the year 2022;

WHEREAS, electricity is cleanest form of energy which helps in mitigating house hold air pollution which is matter of concern;

WHEREAS, there is need to provide electricity supply to people who do not yet have access to it;

WHEREAS, taking into consideration the technical challenges and time requirements for installation of FGD and other technologies to meet the new emission limits, the MoEF&CC vide its letter F. No. Q-15017/40/2007-CPW dated 07.12.2017 has directed CPCB to direct all the thermal power plants to ensure compliance with the norms laid down in the 07.12.2015 notification in accordance with the revised Plan submitted by the Ministry of Power letter dated 13.10.2017 as well as NOx by 2022;

WHEREAS, the Ministry of Environment, Forest & Climate Change, Government of India, vide Notifications No. S. O. 157 (E) of 27.02.1996 and S. O. 730 (E) dated 10.07.2002, has delegated the powers vested under Section 5 of the Environment (Protection) Act, 1986 (29 of 1986) to the Chairman, Central Pollution Control Board, to issue directions to any industry or any local body or any other authority for violations of the standards and rules notified under the Environment (Protection) Rules, 1986 and amendment thereof.

NOW, THEREFORE, taking into consideration all material facts including environmental concerns and ensuring stability of power supply and need for phasing the implementation, in exercise of powers vested under Section 5 of the Environment (Protection) Act, 1986, following directions are issued to M/s Tenughat Thermal Power Station, Tenughat Valley Corporation

- i. That plant shall install/retrofit Electrostatic Precipitators (ESP) December 31, 2020 in unit 1 so as to comply PM emission limit
- ii. That plant shall install FGD by December 31 2020 in unit 1& 2 respectively so as to comply SO<sub>2</sub> emission limit
- iii. That plant shall take immediate measure like installation of low NOx burners, providing Over Fire Air (OFA) etc. and achieve progressive reduction so as to comply NOx emission limit by the year 2022

The time line mentioned above (i to iii) for compliance of PM, SO<sub>2</sub> & NOx emission limits shall be reviewed by CPCB within a period of three months and shall be brought down further considering the location specificity of the plant such as critical polluted area/ closeness to habitation/ urban area.

The time line for compliance of water consumption limit shall also be finalised in consultation of plants


M/s Tenughat Thermal Power Station, Tenughat Valley Corporation shall ensure compliance of directions mentioned above (i to iii) failing which action will be taken under the appropriate provisions of the Environment (Protection) Act, 1986.

  
(A.K. Mehta)  
Chairman



**Copy to:**

1. The Chairman  
Jharkhand State Pollution Control Board  
T.A. Bldg., HEC, P. O.  
Dhurwa, Ranchi-834 004 (Jharkhand)
2. The Joint Secretary (CP Division)  
Ministry of Environment, Forests and Climate Change  
Prithvi Wing, 2nd Floor, Room No. 216  
Indira Paryavaran Bhawan, Aliganj,  
Jor Bagh Road, New Delhi - 110003
3. The Joint Secretary (Thermal)  
Ministry of Power  
Shram Shakti Bhawan, Rafi Marg  
New Delhi
4. The Regional Director,  
Central Pollution Control Board  
Southend Conclave, Block 502, 5th & 6th Floor  
1582, Rajdanga Main Road  
Kolkata - 700 107
- ✓ 5. The Divisional Head - IT, CPCB



(A. Sudhakar)  
Member Secretary

SPEED POST

B-33014/07/2017-18/IPC-II/TPP/

December 11, 2017

To

The General Manager  
M/s Maithan Power Ltd.  
Maithan, Dhanbad-828205,  
Jharkhand

**Sub: Directions under Section 5 of the Environment (Protection) Act, 1986 regarding compliance of emission limit notified vide notification No.S.O.3305 (E) dated 07.12.2015 - reg.**

WHEREAS, taking into consideration pollution from thermal power plants, Ministry of Environment, Forest & Climate Change had issued notification in the year 1984 laying out standards for thermal power plants. Further, the stack height regulation was notified in the year 1989 and effluent standard for thermal power plants was notified in the year 1986. The revised temperature limit of discharge of cooling water from the plants was notified in the year 1999 and thereafter use of beneficiated coal in the plants was issued in June 2002. The fly ash utilization notification was also issued on 14th September, 1999 and amended in the year 2003 and 2009. Thereafter, MoEF&CC vide Notification No. S.O.3305(E) dated 07.12.2015 has amended emission limit for particulate matter and notified new limits for Sulphur dioxide (SO<sub>2</sub>), Oxides of Nitrogen (NO<sub>x</sub>) and mercury emission, and water consumption limit for coal/lignite based thermal power plants. As per the notification dated 07.12.2015, thermal power plants are required to achieve the notified limit within two years from the date of the notification i.e. by 07.12.2017;

WHEREAS, with the implementation of the amendment dated 07.12.2015, it is expected that there would be reduction in emission of PM, Sulphur dioxide and oxide of Nitrogen, which in turn will help in improvement in Ambient Air Quality in and around thermal power plants, besides reduction of mercury emission and water use in the thermal power plants will reduce;

WHEREAS, in the meeting on Coal Washeries (Environment & Forest Clearances) and Emission Norms for Thermal Power Plants chaired by the Hon'ble Minister of Environment, Forest & Climate Change and Minister of Power, Coal & Renewable Energy on June 08, 2016, it was decided that a committee comprising representatives from MoEF & CC, Ministry of Power (MoP), Central electricity Authority (CEA), Ministry of Coal (MoC), Power Grid Corporation of India Limited (PGCI) and Central Pollution Control Board (CPCB) may be constituted to look into the all issues related to implementation of norms;



WHEREAS, following decisions were taken in the meeting:

1. MoP/CEA shall submit action plan by December 2016 for phasing out of the power plants commissioned before December, 2003.
2. MoP / CEA shall submit action plan by December, 2016 in respect of power plants commissioned during January, 2004 to December, 2016 indicating unit wise retrofit / renovation for each power plant. The implementation of action plan shall be taken up in backward manner starting from the plants commissioned in the 2015 and the shall be completed by 15.08.2022
3. MoP and CEA shall coordinate with each State Public Sector Undertakings separately for submission of action plan by December, 2016 for all the power plants.

WHEREAS, it was further decided that MoP shall take action for installation of Flue gas Desulphurisation (FGD) if needed to achieve prescribed SO<sub>2</sub> norms based on the SO<sub>2</sub> emission levels from power plants;

WHEREAS, it was also pointed out that NO<sub>x</sub> control technology in case of Indian coal is not established. Selective Catalytic Reduction (SCR) technology is used for NO<sub>x</sub> control, however, its feasibility for Indian coal needs to be established. MoP suggested that Pilot studies may be taken up in two plants and based on the results, further action plan to be drawn regarding retrofitting of SCR in plants to achieve prescribed NO<sub>x</sub> norms;

WHEREAS, the MoP constituted a committee under the Chairmanship of Chairman, Central Electricity Authority (CEA) on 21.09.2016 to prepare an action plan for implementation of new emission limits;

WHEREAS, to ensure compliance of the new emission norms the MOEF&CC convened a meeting on 23.05.2017 in which CEA, NTPC and the Central Pollution Control Board participated;

WHEREAS, the MOEF&CC received a letter from Secretary Ministry of Power *vide* their D.O. letter No. FU-1/2016-IPC dated 30<sup>th</sup> June, 2017 indicating the concerns of various thermal power plants in the country with regard to the compliance with the new emission norms for the thermal power plants notified on 7.12.2015 particularly w.r.t. Particulate Matter (PM), Sulphur dioxide (SO<sub>2</sub>) & Oxides of Nitrogen (NO<sub>x</sub>);

WHEREAS, it was noted that out of present 196667 MW installed capacity, about 60 % capacity (1,15,214 MW) meets the new PM norms with existing ESP installations. Remaining capacity of 64,334 MW which does not meet the new environmental norms regarding PM, requiring retrofitting additional fields in Electrostatic Precipitator (ESP)/replacement of ESP in existing plants to meet the new emission norms of PM;



WHEREAS, Ministry of Power after consultation with Central electricity Authority informed that retrofitting additional fields in ESP/replacement of ESP in existing plants will need complete shutdown of 4-6 months for each unit;

WHEREAS, in order to meet SO<sub>2</sub> emission norms, FGD system shall be required to be installed in all plants. MoP informed that about 30-36 months required for design & engineering, approvals, funds arrangements, tendering, erection and commissioning of FGD. Besides, planned shutdown will be required as all plants cannot be shut down simultaneously. Another challenge highlighted for installation of FGD was availability of technologies/suppliers. In addition, issues relating to availability of good quality lime stone for operation of FGD and disposal of Gypsum to run the FGD in existing plants were also taken note of;

WHEREAS, the standard of 300 & 100 mg/NM<sup>3</sup> would require installation of Selective Non Catalytic Reduction (SNCR) or Selective Non Catalytic Reduction (SCR). While these technologies are established globally, these are not established for Indian Coal, which has high ash content. Therefore, it was decided to engage various technology vendors to run pilots at NTPC stations to validate technology of SNCR/SCR system for Indian coal;

WHEREAS, the Ministry of Power in the letter dated 30.06.2017 enclosed the report outlining the plan of action for implementation of the new norms keeping in mind the techno-economic feasibility and ensuring availability of power to all at affordable cost without any disruption;

WHEREAS, as per the phasing plan proposed by MOP after consultation with CEA and Regional Power Committees, out of the installed capacity of 1, 87,162 MW ( as on December, 2016), 8217 MW have been identified for retirement/already retired. Further, 12,974 MW of capacity already have either CFBC boilers or FGDs.

WHEREAS, a phasing plan was proposed for the balance 165971 MW of coal based thermal capacity for achieving compliance with 145977 MW capacity proposing installation of FGDs within a period of 7 years to be undertaken in a phased manner. About 3205 MW of coal based capacity was stated to be compliant with revised norms of SO<sub>2</sub> emission;

WHEREAS, it was further noted that approximately about 16789 MW would not be able to install FGDs due to various constraints which include lack of space, etc.;

WHEREAS, CEA has worked out the requirement of capacity of coal based thermal power plants including hydro, wind, solar, gas based units to meet the estimated peak demand of 225 GW in 2021-22;

WHEREAS, MoP suggested that the compliance period of PM for the plants installing FGD may be kept same as per the FGD phasing plan;

WHEREAS, it was requested that for implementation of NO<sub>x</sub> norms in the plants installed before 31.12.2003 a period of three years may be permitted to achieve specified standards of 600 mg/Nm<sup>3</sup>. For other plants a relaxation of 600 mg/Nm<sup>3</sup> in place of 300 and 100 mg/Nm<sup>3</sup> for a period of 3 years was also requested;

WHEREAS, taking into account the issues/concerns raised by the MoP and the sensitivity involved in the matter as it relates to general public of the country, the Ministry undertook detailed analysis of each of the issues in the meetings held on 06.07.2017, 27.07.2017, 11.08.2017 and 01.09.2017. These meetings were also attended by the various stakeholders including Ministry of Power, CEA, NTPC etc.;

WHEREAS, MOEF & CC in the meeting with MoP, CEA, NTPC & CPCB etc. held on September 1, 2017 decided that the action plan submitted by MoP for 7 years i.e. up to 2024 was too long and it should instead commence from 2018 and implemented by 2022 with respect to all pollutants. It was further suggested that action plan should be revised prioritising the plants located in critically polluted area /close to habitation /urban area. Based on the decisions taken in the meeting Ministry of Power vide letter No. FU-1/2017-IPC dated 13.10.2017 submitted the revised action plan, to implement/phasing FGD installation/ ESP upgradation to meet new emission norms for thermal power plants;

WHEREAS, as per the revised plan submitted by the MoP vide letter dated 13.10.2017, 650 units comprising 196667 MW need to meet the new emission limits. Out of 650 units, FGD will be installed to achieve the emission limit of SO<sub>2</sub> by the year 2022 in all 415 units comprising 161522 MW (01 unit by 2018, 08 units by 2019, and 55 units by 2020, 172 units by 2021 and 178 units by 2022, for 01 units with 150 MW capacity plan is not received). Remaining 235 units comprised of 35145 MW either complying with SO<sub>2</sub> emission limits or planned for phasing out;

WHEREAS, ESP upgradation to achieve emission limit of particulate matter will be completed by the year 2022 in PM for 231 units comprising of 65925 MW capacity out of 650 units (01 unit by 2018, 02 units by 2019, 28 units by 2020, 97 units by 2021 and 94 units by 2022, for 09 units of 1400 MW capacity plan by 2022);

WHEREAS, with regard to compliance of emission limit of NO<sub>x</sub>, it is suggested that pre combustion modification such as in situ modification in boiler, installation of Low NO<sub>x</sub> burners and Over Fire Air shall be adopted besides installation of SCR/SNCR systems wherever needed by the year 2022;

WHEREAS, electricity is cleanest form of energy which helps in mitigating house hold air pollution which is matter of concern;

WHEREAS, there is need to provide electricity supply to people who do not yet have access to it;

WHEREAS, taking into consideration the technical challenges and time requirements for installation of FGD and other technologies to meet the new emission limits, the MoEF&CC vide its letter F. No. Q-15017/40/2007-CPW dated 07.12.2017 has directed CPCB to direct all the thermal power plants to ensure compliance with the norms laid down in the 07.12.2015 notification in accordance with the revised Plan submitted by the Ministry of Power letter dated 13.10.2017 as well as NOx by 2022;

WHEREAS, the Ministry of Environment, Forest & Climate Change, Government of India, vide Notifications No. S. O. 157 (E) of 27.02.1996 and S. O. 730 (E) dated 10.07.2002, has delegated the powers vested under Section 5 of the Environment (Protection) Act, 1986 (29 of 1986) to the Chairman, Central Pollution Control Board, to issue directions to any industry or any local body or any other authority for violations of the standards and rules notified under the Environment (Protection) Rules, 1986 and amendment thereof.



NOW, THEREFORE, taking into consideration all material facts including environmental concerns and ensuring stability of power supply and need for phasing the implementation, in exercise of powers vested under Section 5 of the Environment (Protection) Act, 1986, following directions are issued to M/s Maithon Thermal Power Station, Maithon

- i. That plant shall install/retrofit Electrostatic Precipitators ( ESP) so as to comply PM emission limit immediately
- ii. That plant shall install FGD by September 30, 2021 & June 30, 2022 in unit 1& 2 respectively so as to comply SO<sub>2</sub> emission limit
- iii. That plant shall take immediate measure like installation of low NOx burners, providing Over Fire Air ( OFA) etc. and achieve progressive reduction so as to comply NOx emission limit by the year 2022

The time line mentioned above (i to iii) for compliance of PM, SO<sub>2</sub> & NOx emission limits shall be reviewed by CPCB within a period of three months and shall be brought down further considering the location specificity of the plant such as critical polluted area/ closeness to habitation/ urban area.


The time line for compliance of water consumption limit shall also be finalised in consultation of plants

M/s Maithon Thermal Power Station, Maithon shall ensure compliance of directions mentioned above (i to iii) failing which action will be taken under the appropriate provisions of the Environment (Protection) Act, 1986.

  
(A.K. Mehta)  
Chairman  


**Copy to:**

1. The Chairman  
Jharkhand State Pollution Control Board  
T.A. Bldg., HEC, P. O.  
Dhurwa, Ranchi-834 004 (Jharkhand)
2. The Joint Secretary (CP Division)  
Ministry of Environment, Forests and Climate Change  
Prithvi Wing, 2nd Floor, Room No. 216  
Indira Paryavaran Bhawan, Aliganj,  
Jor Bagh Road, New Delhi - 110003
3. The Joint Secretary (Thermal)  
Ministry of Power  
Shram Shakti Bhawan, Rafi Marg  
New Delhi
4. The Regional Director,  
Central Pollution Control Board  
Southend Conclave, Block 502, 5th & 6th Floor  
1582, Rajdanga Main Road  
Kolkata - 700 107
- ✓ 5. The Divisional Head - IT, CPCB



(A. Sudhakar)  
Member Secretary



SPEED POST

B-33014/07/2017-18/IPC-II/TPP/

December 11, 2017

To

The General Manager  
M/s Koderma Thermal Power Station,  
Koderma. 825421  
Jharkhand

Sub: **Directions under Section 5 of the Environment (Protection) Act, 1986 regarding compliance of emission limit notified vide notification No.S.O.3305 (E) dated 07.12.2015 - reg.**

WHEREAS, taking into consideration pollution from thermal power plants, Ministry of Environment, Forest & Climate Change had issued notification in the year 1984 laying out standards for thermal power plants. Further, the stack height regulation was notified in the year 1989 and effluent standard for thermal power plants was notified in the year 1986. The revised temperature limit of discharge of cooling water from the plants was notified in the year 1999 and thereafter use of beneficiated coal in the plants was issued in June 2002. The fly ash utilization notification was also issued On 14th September, 1999 and amended in the year 2003 and 2009. Thereafter, MoEF&CC vide Notification No. S.O.3305(E) dated 07.12.2015 has amended emission limit for particulate matter and notified new limits for Sulphur dioxide (SO<sub>2</sub>), Oxides of Nitrogen (NO<sub>x</sub>) and mercury emission, and water consumption limit for coal/lignite based thermal power plants. As per the notification dated 07.12.2015, thermal power plants are required to achieve the notified limit within two years from the date of the notification i.e. by 07.12.2017;

WHEREAS, with the implementation of the amendment dated 07.12.2015, it is expected that there would be reduction in emission of PM, Sulphur dioxide and oxide of Nitrogen, which in turn will help in improvement in Ambient Air Quality in and around thermal power plants, besides reduction of mercury emission and water use in the thermal power plants will reduce;

WHEREAS, in the meeting on Coal Washeries (Environment & Forest Clearances) and Emission Norms for Thermal Power Plants chaired by the Hon'ble Minister of Environment, Forest & Climate Change and Minister of Power, Coal & Renewable Energy on June 08, 2016, it was decided that a committee comprising representatives from MoEF & CC, Ministry of Power (MoP), Central electricity Authority (CEA), Ministry of Coal (MoC), Power Grid Corporation of India Limited (PGCI) and Central Pollution Control Board (CPCB) may be constituted to look into the all issues related to implementation of norms;



WHEREAS, following decisions were taken in the meeting:

1. MoP/CEA shall submit action plan by December 2016 for phasing out of the power plants commissioned before December, 2003.
2. MoP / CEA shall submit action plan by December, 2016 in respect of power plants commissioned during January, 2004 to December, 2016 indicating unit wise retrofit / renovation for each power plant. The implementation of action plan shall be taken up in backward manner starting from the plants commissioned in the 2015 and the shall be completed by 15.08.2022
3. MoP and CEA shall coordinate with each State Public Sector Undertakings separately for submission of action plan by December, 2016 for all the power plants.

WHEREAS, it was further decided that MoP shall take action for installation of Flue gas Desulphurisation (FGD) if needed to achieve prescribed SO<sub>2</sub> norms based on the SO<sub>2</sub> emission levels from power plants;

WHEREAS, it was also pointed out that NO<sub>x</sub> control technology in case of Indian coal is not established. Selective Catalytic Reduction (SCR) technology is used for NO<sub>x</sub> control, however, its feasibility for Indian coal needs to be established. MoP suggested that Pilot studies may be taken up in two plants and based on the results, further action plan to be drawn regarding retrofitting of SCR in plants to achieve prescribed NO<sub>x</sub> norms;

WHEREAS, the MoP constituted a committee under the Chairmanship of Chairman, Central Electricity Authority (CEA) on 21.09.2016 to prepare an action plan for implementation of new emission limits;

WHEREAS, to ensure compliance of the new emission norms the MOEF&CC convened a meeting on 23.05.2017 in which CEA, NTPC and the Central Pollution Control Board participated;

WHEREAS, the MOEF&CC received a letter from Secretary Ministry of Power *vide* their D.O. letter No. FU-1/2016-IPC dated 30<sup>th</sup> June, 2017 indicating the concerns of various thermal power plants in the country with regard to the compliance with the new emission norms for the thermal power plants notified on 7.12.2015 particularly w.r.t. Particulate Matter (PM), Sulphur dioxide (SO<sub>2</sub>) & Oxides of Nitrogen (NO<sub>x</sub>);

WHEREAS, it was noted that out of present 196667 MW installed capacity, about 60 % capacity (1,15,214 MW) meets the new PM norms with existing ESP installations. Remaining capacity of 64,334 MW which does not meet the new environmental norms regarding PM, requiring retrofitting additional fields in Electrostatic Precipitator (ESP)/replacement of ESP in existing plants to meet the new emission norms of PM;

WHEREAS, Ministry of Power after consultation with Central electricity Authority informed that retrofitting additional fields in ESP/replacement of ESP in existing plants will need complete shutdown of 4-6 months for each unit;

WHEREAS, in order to meet SO<sub>2</sub> emission norms, FGD system shall be required to be installed in all plants. MoP informed that about 30-36 months required for design & engineering, approvals, funds arrangements, tendering, erection and commissioning of FGD. Besides, planned shutdown will be required as all plants cannot be shut down simultaneously. Another challenge highlighted for installation of FGD was availability of technologies/suppliers. In addition, issues relating to availability of good quality lime stone for operation of FGD and disposal of Gypsum to run the FGD in existing plants were also taken note of;

WHEREAS, the standard of 300 & 100 mg/NM<sup>3</sup> would require installation of Selective Non Catalytic Reduction (SNCR) or Selective Non Catalytic Reduction (SCR). While these technologies are established globally, these are not established for Indian Coal, which has high ash content. Therefore, it was decided to engage various technology vendors to run pilots at NTPC stations to validate technology of SNCR/SCR system for Indian coal;

WHEREAS, the Ministry of Power in the letter dated 30.06.2017 enclosed the report outlining the plan of action for implementation of the new norms keeping in mind the techno-economic feasibility and ensuring availability of power to all at affordable cost without any disruption;

WHEREAS, as per the phasing plan proposed by MOP after consultation with CEA and Regional Power Committees, out of the installed capacity of 1, 87,162 MW ( as on December, 2016), 8217 MW have been identified for retirement/already retired. Further, 12,974 MW of capacity already have either CFBC boilers or FGDs.

WHEREAS, a phasing plan was proposed for the balance 165971 MW of coal based thermal capacity for achieving compliance with 145977 MW capacity proposing installation of FGDs within a period of 7 years to be undertaken in a phased manner. About 3205 MW of coal based capacity was stated to be compliant with revised norms of SO<sub>2</sub> emission;

WHEREAS, it was further noted that approximately about 16789 MW would not be able to install FGDs due to various constraints which include lack of space, etc.;

WHEREAS, CEA has worked out the requirement of capacity of coal based thermal power plants including hydro, wind, solar, gas based units to meet the estimated peak demand of 225 GW in 2021-22;

WHEREAS, MoP suggested that the compliance period of PM for the plants installing FGD may be kept same as per the FGD phasing plan;

WHEREAS, it was requested that for implementation of NO<sub>x</sub> norms in the plants installed before 31.12.2003 a period of three years may be permitted to achieve specified standards of 600 mg/Nm<sup>3</sup>. For other plants a relaxation of 600 mg/Nm<sup>3</sup> in place of 300 and 100 mg/Nm<sup>3</sup> for a period of 3 years was also requested;

WHEREAS, taking into account the issues/concerns raised by the MoP and the sensitivity involved in the matter as it relates to general public of the country, the Ministry undertook detailed analysis of each of the issues in the meetings held on 06.07.2017, 27.07.2017, 11.08.2017 and 01.09.2017. These meetings were also attended by the various stakeholders including Ministry of Power, CEA, NTPC etc.;

WHEREAS, MOEF & CC in the meeting with MoP, CEA, NTPC & CPCB etc. held on September 1, 2017 decided that the action plan submitted by MoP for 7 years i.e. up to 2024 was too long and it should instead commence from 2018 and implemented by 2022 with respect to all pollutants. It was further suggested that action plan should be revised prioritising the plants located in critically polluted area /close to habitation /urban area. Based on the decisions taken in the meeting Ministry of Power vide letter No. FU-1/2017-IPC dated 13.10.2017 submitted the revised action plan, to implement/phasing FGD installation/ ESP upgradation to meet new emission norms for thermal power plants;

WHEREAS, as per the revised plan submitted by the MoP vide letter dated 13.10.17, 650 units comprising 196667 MW need to meet the new emission limits. Out of 650 units, FGD will be installed to achieve the emission limit of SO<sub>2</sub> by the year 2022 in all 415 units comprising 161522 MW (01 unit by 2018, 08 units by 2019, and 55 units by 2020, 172 units by 2021 and 178 units by 2022, for 01 units with 150 MW capacity plan is not received). Remaining 235 units comprised of 35145 MW either complying with SO<sub>2</sub> emission limits or planned for phasing out;

WHEREAS, ESP upgradation to achieve emission limit of particulate matter will be completed by the year 2022 in PM for 231 units comprising of 65925 MW capacity out of 650 units (01 unit by 2018, 02 units by 2019, 28 units by 2020, 97 units by 2021 and 94 units by 2022, for 09 units of 1400 MW capacity plan by 2022);

WHEREAS, with regard to compliance of emission limit of NO<sub>x</sub>, it is suggested that pre combustion modification such as in situ modification in boiler, installation of Low NO<sub>x</sub> burners and Over Fire Air shall be adopted besides installation of SCR/SNCR systems wherever needed by the year 2022;

WHEREAS, electricity is cleanest form of energy which helps in mitigating house hold air pollution which is matter of concern;

WHEREAS, there is need to provide electricity supply to people who do not yet have access to it;

WHEREAS, taking into consideration the technical challenges and time requirements for installation of FGD and other technologies to meet the new emission limits, the MoEF&CC vide its letter F. No. Q-15017/40/2007-CPW dated 07.12.2017 has directed CPCB to direct all the thermal power plants to ensure compliance with the norms laid down in the 07.12.2015 notification in accordance with the revised Plan submitted by the Ministry of Power letter dated 13.10.2017 as well as NOx by 2022;

WHEREAS, the Ministry of Environment, Forest & Climate Change, Government of India, vide Notifications No. S. O. 157 (E) of 27.02.1996 and S. O. 730 (E) dated 10.07.2002, has delegated the powers vested under Section 5 of the Environment (Protection) Act, 1986 (29 of 1986) to the Chairman, Central Pollution Control Board, to issue directions to any industry or any local body or any other authority for violations of the standards and rules notified under the Environment (Protection) Rules, 1986 and amendment thereof.

NOW, THEREFORE, taking into consideration all material facts including environmental concerns and ensuring stability of power supply and need for phasing the implementation, in exercise of powers vested under Section 5 of the Environment (Protection) Act, 1986, following directions are issued to M/s Koderma Thermal Power Station

- i. That plant shall install/retrofit Electrostatic Precipitators ( ESP) so as to comply PM emission limit immediately
- ii. That plant shall install FGD by December 31 2021 in unit 1& 2 respectively so as to comply SO<sub>2</sub> emission limit
- iii. That plant shall take immediate measure like installation of low NOx burners, providing Over Fire Air ( OFA) etc. and achieve progressive reduction so as to comply NOx emission limit by the year 2022

The time line mentioned above (i to iii) for compliance of PM, SO<sub>2</sub> & NOx emission limits shall be reviewed by CPCB within a period of three months and shall be brought down further considering the location specificity of the plant such as critical polluted area/ closeness to habitation/ urban area.

The time line for compliance of water consumption limit shall also be finalised in consultation of plants


M/s Koderma Thermal Power Station shall ensure compliance of directions mentioned above (i to iii) failing which action will be taken under the appropriate provisions of the Environment (Protection) Act, 1986.

  
(A.R. Mehta)  
Chairman



Copy to:

1. The Chairman  
Jharkhand State Pollution Control Board  
T.A. Bldg., HEC, P. O.  
Dhurwa, Ranchi-834 004 (Jharkhand)
2. The Joint Secretary (CP Division)  
Ministry of Environment, Forests and Climate Change  
Prithvi Wing, 2nd Floor, Room No. 216  
Indira Paryavaran Bhawan, Aliganj,  
Jor Bagh Road, New Delhi - 110003
3. The Joint Secretary (Thermal)  
Ministry of Power  
Shram Shakti Bhawan, Rafi Marg  
New Delhi
4. The Regional Director,  
Central Pollution Control Board  
Southend Conclave, Block 502, 5th & 6th Floor  
1582, Rajdanga Main Road  
Kolkata - 700 107
- ✓ 5. The Divisional Head - IT, CPCB



(A. Sudhakar)  
Member Secretary



SPEED POST

B-33014/07/2017-18/IPC-II/TPP/

December 11, 2017

To

M/s Adhunik Power & Natural Resources Limited  
Village Padampur, Behind PGCIL Substation  
Adityapur, Kandra Road, Po- Kandra  
Saraikela - Kharsawan- 832 402, Jharkhand

**Sub: Directions under Section 5 of the Environment (Protection) Act, 1986 regarding compliance of emission limit notified vide notification No.S.O.3305 (E) dated 07.12.2015 - reg.**

WHEREAS, taking into consideration pollution from thermal power plants, Ministry of Environment, Forest & Climate Change had issued notification in the year 1984 laying out standards for thermal power plants. Further, the stack height regulation was notified in the year 1989 and effluent standard for thermal power plants was notified in the year 1986. The revised temperature limit of discharge of cooling water from the plants was notified in the year 1999 and thereafter use of beneficiated coal in the plants was issued in June 2002. The fly ash utilization notification was also issued On 14th September, 1999 and amended in the year 2003 and 2009. Thereafter, MoEF&CC vide Notification No. S.O.3305(E) dated 07.12.2015 has amended emission limit for particulate matter and notified new limits for Sulphur dioxide (SO<sub>2</sub>), Oxides of Nitrogen (NO<sub>x</sub>) and mercury emission, and water consumption limit for coal/lignite based thermal power plants. As per the notification dated 07.12.2015, thermal power plants are required to achieve the notified limit within two years from the date of the notification i.e. by 07.12.2017;

WHEREAS, with the implementation of the amendment dated 07.12.2015, it is expected that there would be reduction in emission of PM, Sulphur dioxide and oxide of Nitrogen, which in turn will help in improvement in Ambient Air Quality in and around thermal power plants, besides reduction of mercury emission and water use in the thermal power plants will reduce;

WHEREAS, in the meeting on Coal Washeries (Environment & Forest Clearances) and Emission Norms for Thermal Power Plants chaired by the Hon'ble Minister of Environment, Forest & Climate Change and Minister of Power, Coal & Renewable Energy on June 08, 2016, it was decided that a committee comprising representatives from MoEF & CC, Ministry of Power (MoP), Central electricity Authority (CEA), Ministry of Coal (MoC), Power Grid Corporation of India Limited (PGCI) and Central Pollution Control Board (CPCB) may be constituted to look into the all issues related to implementation of norms;

WHEREAS, following decisions were taken in the meeting:

1. MoP/CEA shall submit action plan by December 2016 for phasing out of the power plants commissioned before December, 2003.
2. MoP / CEA shall submit action plan by December, 2016 in respect of power plants commissioned during January, 2004 to December, 2016 indicating unit wise retrofit / renovation for each power plant. The implementation of action plan shall be taken up in backward manner starting from the plants commissioned in the 2015 and the shall be completed by 15.08.2022
3. MoP and CEA shall coordinate with each State Public Sector Undertakings separately for submission of action plan by December, 2016 for all the power plants.

WHEREAS, it was further decided that MoP shall take action for installation of Flue gas Desulphurisation (FGD) if needed to achieve prescribed SO<sub>2</sub> norms based on the SO<sub>2</sub> emission levels from power plants;

WHEREAS, it was also pointed out that NO<sub>x</sub> control technology in case of Indian coal is not established. Selective Catalytic Reduction (SCR) technology is used for NO<sub>x</sub> control, however, its feasibility for Indian coal needs to be established. MoP suggested that Pilot studies may be taken up in two plants and based on the results, further action plan to be drawn regarding retrofitting of SCR in plants to achieve prescribed NO<sub>x</sub> norms;

WHEREAS, the MoP constituted a committee under the Chairmanship of Chairman, Central Electricity Authority (CEA) on 21.09.2016 to prepare an action plan for implementation of new emission limits;

WHEREAS, to ensure compliance of the new emission norms the MOEF&CC convened a meeting on 23.05.2017 in which CEA, NTPC and the Central Pollution Control Board participated;

WHEREAS, the MOEF&CC received a letter from Secretary Ministry of Power *vide* their D.O. letter No. FU-1/2016-IPC dated 30<sup>th</sup> June, 2017 indicating the concerns of various thermal power plants in the country with regard to the compliance with the new emission norms for the thermal power plants notified on 7.12.2015 particularly w.r.t. Particulate Matter (PM), Sulphur dioxide (SO<sub>2</sub>) & Oxides of Nitrogen (NO<sub>x</sub>);

WHEREAS, it was noted that out of present 196667 MW installed capacity, about 60 % capacity (1,15,214 MW) meets the new PM norms with existing ESP installations. Remaining capacity of 64,334 MW which does not meet the new environmental norms regarding PM, requiring retrofitting additional fields in Electrostatic Precipitator (ESP)/replacement of ESP in existing plants to meet the new emission norms of PM;

WHEREAS, Ministry of Power after consultation with Central electricity Authority informed that retrofitting additional fields in ESP/replacement of ESP in existing plants will need complete shutdown of 4-6 months for each unit;

WHEREAS, in order to meet SO<sub>2</sub> emission norms, FGD system shall be required to be installed in all plants. MoP informed that about 30-36 months required for design & engineering, approvals, funds arrangements, tendering, erection and commissioning of FGD. Besides, planned shutdown will be required as all plants cannot be shut down simultaneously. Another challenge highlighted for installation of FGD was availability of technologies/suppliers. In addition, issues relating to availability of good quality lime stone for operation of FGD and disposal of Gypsum to run the FGD in existing plants were also taken note of;

WHEREAS, the standard of 300 & 100 mg/NM<sup>3</sup> would require installation of Selective Non Catalytic Reduction (SNCR) or Selective Non Catalytic Reduction (SCR). While these technologies are established globally, these are not established for Indian Coal, which has high ash content. Therefore, it was decided to engage various technology vendors to run pilots at NTPC stations to validate technology of SNCR/SCR system for Indian coal;

WHEREAS, the Ministry of Power in the letter dated 30.06.2017 enclosed the report outlining the plan of action for implementation of the new norms keeping in mind the techno-economic feasibility and ensuring availability of power to all at affordable cost without any disruption;

WHEREAS, as per the phasing plan proposed by MOP after consultation with CEA and Regional Power Committees, out of the installed capacity of 1, 87,162 MW ( as on December, 2016), 8217 MW have been identified for retirement/already retired. Further, 12,974 MW of capacity already have either CFBC boilers or FGDs.

WHEREAS, a phasing plan was proposed for the balance 165971 MW of coal based thermal capacity for achieving compliance with 145977 MW capacity proposing installation of FGDs within a period of 7 years to be undertaken in a phased manner. About 3205 MW of coal based capacity was stated to be compliant with revised norms of SO<sub>2</sub> emission; --

WHEREAS, it was further noted that approximately about 16789 MW would not be able to install FGDs due to various constraints which include lack of space, etc.;

WHEREAS, CEA has worked out the requirement of capacity of coal based thermal power plants including hydro, wind, solar, gas based units to meet the estimated peak demand of 225 GW in 2021-22;

WHEREAS, MoP suggested that the compliance period of PM for the plants installing FGD may be kept same as per the FGD phasing plan;



WHEREAS, it was requested that for implementation of NO<sub>x</sub> norms in the plants installed before 31.12.2003 a period of three years may be permitted to achieve specified standards of 600 mg/Nm<sup>3</sup>. For other plants a relaxation of 600 mg/Nm<sup>3</sup> in place of 300 and 100 mg/Nm<sup>3</sup> for a period of 3 years was also requested;

WHEREAS, taking into account the issues/concerns raised by the MoP and the sensitivity involved in the matter as it relates to general public of the country, the Ministry undertook detailed analysis of each of the issues in the meetings held on 06.07.2017, 27.07.2017, 11.08.2017 and 01.09.2017. These meetings were also attended by the various stakeholders including Ministry of Power, CEA, NTPC etc.;

WHEREAS, MOEF & CC in the meeting with MoP, CEA, NTPC & CPCB etc. held on September 1, 2017 decided that the action plan submitted by MoP for 7 years i.e. up to 2024 was too long and it should instead commence from 2018 and implemented by 2022 with respect to all pollutants. It was further suggested that action plan should be revised prioritising the plants located in critically polluted area /close to habitation /urban area. Based on the decisions taken in the meeting Ministry of Power vide letter No. FU-1/2017-IPC dated 13.10.2017 submitted the revised action plan, to implement/phasing FGD installation/ ESP upgradation to meet new emission norms for thermal power plants;

WHEREAS, as per the revised plan submitted by the MoP vide letter dated 13.10.2017, 650 units comprising 196667 MW need to meet the new emission limits. Out of 650 units, FGD will be installed to achieve the emission limit of SO<sub>2</sub> by the year 2022 in all 415 units comprising 161522 MW (01 unit by 2018, 08 units by 2019, and 55 units by 2020, 172 units by 2021 and 178 units by 2022, for 01 units with 150 MW capacity plan is not received). Remaining 235 units comprised of 35145 MW either complying with SO<sub>2</sub> emission limits or planned for phasing out;

WHEREAS, ESP upgradation to achieve emission limit of particulate matter will be completed by the year 2022 in PM for 231 units comprising of 65925 MW capacity out of 650 units (01 unit by 2018, 02 units by 2019, 28 units by 2020, 97 units by 2021 and 94 units by 2022, for 09 units of 1400 MW capacity plan by 2022);

WHEREAS, with regard to compliance of emission limit of NO<sub>x</sub>, it is suggested that pre combustion modification such as in situ modification in boiler, installation of Low NO<sub>x</sub> burners and Over Fire Air shall be adopted besides installation of SCR/SNCR systems wherever needed by the year 2022;

WHEREAS, electricity is cleanest form of energy which helps in mitigating house hold air pollution which is matter of concern;

WHEREAS, there is need to provide electricity supply to people who do not yet have access to it;



WHEREAS, taking into consideration the technical challenges and time requirements for installation of FGD and other technologies to meet the new emission limits, the MoEF&CC vide its letter F. No. Q-15017/40/2007-CPW dated 07.12.2017 has directed CPCB to direct all the thermal power plants to ensure compliance with the norms laid down in the 07.12.2015 notification in accordance with the revised Plan submitted by the Ministry of Power letter dated 13.10.2017 as well as NOx by 2022;

WHEREAS, the Ministry of Environment, Forest & Climate Change, Government of India, vide Notifications No. S. O. 157 (E) of 27.02.1996 and S. O. 730 (E) dated 10.07.2002, has delegated the powers vested under Section 5 of the Environment (Protection) Act, 1986 (29 of 1986) to the Chairman, Central Pollution Control Board, to issue directions to any industry or any local body or any other authority for violations of the standards and rules notified under the Environment (Protection) Rules, 1986 and amendment thereof.



NOW, THEREFORE, taking into consideration all material facts including environmental concerns and ensuring stability of power supply and need for phasing the implementation, in exercise of powers vested under Section 5 of the Environment (Protection) Act, 1986, following directions are issued to M/s Adhunik Power & Natural Resources Limited:

- i. That plant shall install/retrofit Electrostatic Precipitators ( ESP) so as to comply PM emission limit immediately
- ii. That plant shall install FGD by June 30, 2022 in Unit 1 & 2 so as to comply SO<sub>2</sub> emission limit
- iii. That plant shall take immediate measure like installation of low NOx burners, providing Over Fire Air ( OFA) etc. and achieve progressive reduction so as to comply NOx emission limit by the year 2022

The time line mentioned above (i to iii) for compliance of PM, SO<sub>2</sub> & NOx emission limits shall be reviewed by CPCB within a period of three months and shall be brought down further considering the location specificity of the plant such as critical polluted area/ closeness to habitation/ urban area.


The time line for compliance of water consumption limit shall also be finalised in consultation of plants

M/s Adhunik Power & Natural Resources Limited shall ensure compliance of directions mentioned above (i to iii) failing which action will be taken under the appropriate provisions of the Environment (Protection) Act, 1986.

  
(A.K. Mehta)  
Chairman  


**Copy to:**

1. The Chairman  
Jharkhand State Pollution Control Board  
T.A. Bldg., IIEC, P. O.  
Dhurwa, Ranchi-834 004 (Jharkhand)
2. The Joint Secretary (CP Division)  
Ministry of Environment, Forests and Climate Change  
Prithvi Wing, 2nd Floor, Room No. 216  
Indira Paryavaran Bhawan, Aliganj,  
Jor Bagh Road, New Delhi - 110003
3. The Joint Secretary (Thermal)  
Ministry of Power  
Shram Shakti Bhawan, Rafi Marg  
New Delhi
4. The Regional Director,  
Central Pollution Control Board  
Southend Conclave, Block 502, 5th & 6th Floor  
1582, Rajdanga Main Road  
Kolkata - 700 107
5. The Divisional Head - IT, CPCB

  
(A. Sudhakar)  
Member Secretary

SPEED POST

B-33014/07/2017-18/IPC-II/TPP/

December 11, 2017

To

M/s Bokaro Thermal Power Station  
Domodar Valley Corporation  
Bokaro -829107; Jharkhand

**Sub: Directions under Section 5 of the Environment (Protection) Act, 1986 regarding compliance of emission limit notified vide notification No.S.O.3305 (E) dated 07.12.2015 - reg.**

WHEREAS, taking into consideration pollution from thermal power plants, Ministry of Environment, Forest & Climate Change had issued notification in the year 1984 laying out standards for thermal power plants. Further, the stack height regulation was notified in the year 1989 and effluent standard for thermal power plants was notified in the year 1986. The revised temperature limit of discharge of cooling water from the plants was notified in the year 1999 and thereafter use of beneficiated coal in the plants was issued in June 2002. The fly ash utilization notification was also issued On 14th September, 1999 and amended in the year 2003 and 2009. Thereafter, MoEF&CC vide Notification No. S.O.3305(E) dated 07.12.2015 has amended emission limit for particulate matter and notified new limits for Sulphur dioxide (SO<sub>2</sub>), Oxides of Nitrogen (NO<sub>x</sub>) and mercury emission, and water consumption limit for coal/lignite based thermal power plants. As per the notification dated 07.12.2015, thermal power plants are required to achieve the notified limit within two years from the date of the notification i.e. by 07.12.2017;

WHEREAS, with the implementation of the amendment dated 07.12.2015, it is expected that there would be reduction in emission of PM, Sulphur dioxide and oxide of Nitrogen, which in turn will help in improvement in Ambient Air Quality in and around thermal power plants, besides reduction of mercury emission and water use in the thermal power plants will reduce;

WHEREAS, in the meeting on Coal Washeries (Environment & Forest Clearances) and Emission Norms for Thermal Power Plants chaired by the Hon'ble Minister of Environment, Forest & Climate Change and Minister of Power, Coal & Renewable Energy on June 08, 2016, it was decided that a committee comprising representatives from MoEF & CC, Ministry of Power (MoP), Central Electricity Authority (CEA), Ministry of Coal (MoC), Power Grid Corporation of India Limited (PGCI) and Central Pollution Control Board (CPCB) may be constituted to look into the all issues related to implementation of norms;

WHEREAS, following decisions were taken in the meeting:

1. MoP/CEA shall submit action plan by December 2016 for phasing out of the power plants commissioned before December, 2003.
2. MoP / CEA shall submit action plan by December, 2016 in respect of power plants commissioned during January, 2004 to December, 2016 indicating unit wise retrofit / renovation for each power plant. The implementation of action plan shall be taken up in backward manner starting from the plants commissioned in the 2015 and the shall be completed by 15.08.2022
3. MoP and CEA shall coordinate with each State Public Sector Undertakings separately for submission of action plan by December, 2016 for all the power plants.

WHEREAS, it was further decided that MoP shall take action for installation of Flue gas Desulphurisation (FGD) if needed to achieve prescribed SO<sub>2</sub> norms based on the SO<sub>2</sub> emission levels from power plants;

WHEREAS, it was also pointed out that NO<sub>x</sub> control technology in case of Indian coal is not established. Selective Catalytic Reduction (SCR) technology is used for NO<sub>x</sub> control, however, its feasibility for Indian coal needs to be established. MoP suggested that Pilot studies may be taken up in two plants and based on the results, further action plan to be drawn regarding retrofitting of SCR in plants to achieve prescribed NO<sub>x</sub> norms;

WHEREAS, the MoP constituted a committee under the Chairmanship of Chairman, Central Electricity Authority (CEA) on 21.09.2016 to prepare an action plan for implementation of new emission limits;

WHEREAS, to ensure compliance of the new emission norms the MOEF&CC convened a meeting on 23.05.2017 in which CEA, NTPC and the Central Pollution Control Board participated;

WHEREAS, the MOEF&CC received a letter from Secretary Ministry of Power *vide* their D.O. letter No. FU-1/2016-IPC dated 30<sup>th</sup> June, 2017 indicating the concerns of various thermal power plants in the country with regard to the compliance with the new emission norms for the thermal power plants notified on 7.12.2015 particularly w.r.t. Particulate Matter (PM), Sulphur dioxide (SO<sub>2</sub>) & Oxides of Nitrogen (NO<sub>x</sub>);

WHEREAS, it was noted that out of present 196667 MW installed capacity, about 60 % capacity (1,15,214 MW) meets the new PM norms with existing ESP installations. Remaining capacity of 64,334 MW which does not meet the new environmental norms regarding PM, requiring retrofitting additional fields in Electrostatic Precipitator (ESP)/replacement of ESP in existing plants to meet the new emission norms of PM;



WHEREAS, Ministry of Power after consultation with Central electricity Authority informed that retrofitting additional fields in ESP/replacement of ESP in existing plants will need complete shutdown of 4-6 months for each unit;

WHEREAS, in order to meet SO<sub>2</sub> emission norms, FGD system shall be required to be installed in all plants. MoP informed that about 30-36 months required for design & engineering, approvals, funds arrangements, tendering, erection and commissioning of FGD. Besides, planned shutdown will be required as all plants cannot be shut down simultaneously. Another challenge highlighted for installation of FGD was availability of technologies/suppliers. In addition, issues relating to availability of good quality lime stone for operation of FGD and disposal of Gypsum to run the FGD in existing plants were also taken note of;

WHEREAS, the standard of 300 & 100 mg/NM<sup>3</sup> would require installation of Selective Non Catalytic Reduction (SNCR) or Selective Non Catalytic Reduction (SCR). While these technologies are established globally, these are not established for Indian Coal, which has high ash content. Therefore, it was decided to engage various technology vendors to run pilots at NTPC stations to validate technology of SNCR/SCR system for Indian coal;

WHEREAS, the Ministry of Power in the letter dated 30.06.2017 enclosed the report outlining the plan of action for implementation of the new norms keeping in mind the techno-economic feasibility and ensuring availability of power to all at affordable cost without any disruption;

WHEREAS, as per the phasing plan proposed by MOP after consultation with CEA and Regional Power Committees, out of the installed capacity of 1, 87,162 MW ( as on December, 2016), 8217 MW have been identified for retirement/already retired. Further, 12,974 MW of capacity already have either CFBC boilers or FGDs.

WHEREAS, a phasing plan was proposed for the balance 165971 MW of coal based thermal capacity for achieving compliance with 145977 MW capacity proposing installation of FGDs within a period of 7 years to be undertaken in a phased manner. About 3205 MW of coal based capacity was stated to be compliant with revised norms of SO<sub>2</sub> emission;

WHEREAS, it was further noted that approximately about 16789 MW would not be able to install FGDs due to various constraints which include lack of space, etc.;

WHEREAS, CEA has worked out the requirement of capacity of coal based thermal power plants including hydro, wind, solar, gas based units to meet the estimated peak demand of 225 GW in 2021-22;

WHEREAS, MoP suggested that the compliance period of PM for the plants installing FGD may be kept same as per the FGD phasing plan;

WHEREAS, it was requested that for implementation of NO<sub>x</sub> norms in the plants installed before 31.12.2003 a period of three years may be permitted to achieve specified standards of 600 mg/Nm<sup>3</sup>. For other plants a relaxation of 600 mg/Nm<sup>3</sup> in place of 300 and 100 mg/Nm<sup>3</sup> for a period of 3 years was also requested;

WHEREAS, taking into account the issues/concerns raised by the MoP and the sensitivity involved in the matter as it relates to general public of the country, the Ministry undertook detailed analysis of each of the issues in the meetings held on 06.07.2017, 27.07.2017, 11.08.2017 and 01.09.2017. These meetings were also attended by the various stakeholders including Ministry of Power, CEA, NTPC etc.;

WHEREAS, MOEF & CC in the meeting with MoP, CEA, NTPC & CPCB etc. held on September 1, 2017 decided that the action plan submitted by MoP for 7 years i.e. up to 2024 was too long and it should instead commence from 2018 and implemented by 2022 with respect to all pollutants. It was further suggested that action plan should be revised prioritising the plants located in critically polluted area /close to habitation /urban area. Based on the decisions taken in the meeting Ministry of Power vide letter No. FU-1/2017-IPC dated 13.10.2017 submitted the revised action plan, to implement/phasing FGD installation/ ESP upgradation to meet new emission norms for thermal power plants;

WHEREAS, as per the revised plan submitted by the MoP vide letter dated 13.10.2017, 650 units comprising 196667 MW need to meet the new emission limits. Out of 650 units, FGD will be installed to achieve the emission limit of SO<sub>2</sub> by the year 2022 in all 415 units comprising 161522 MW (01 unit by 2018, 08 units by 2019, and 55 units by 2020, 172 units by 2021 and 178 units by 2022, for 01 units with 150 MW capacity plan is not received). Remaining 235 units comprised of 35145 MW either complying with SO<sub>2</sub> emission limits or planned for phasing out;

WHEREAS, ESP upgradation to achieve emission limit of particulate matter will be completed by the year 2022 in PM for 231 units comprising of 65925 MW capacity out of 650 units (01 unit by 2018, 02 units by 2019, 28 units by 2020, 97 units by 2021 and 94 units by 2022, for 09 units of 1400 MW capacity plan by 2022);

WHEREAS, with regard to compliance of emission limit of NO<sub>x</sub>, it is suggested that pre combustion modification such as in situ modification in boiler, installation of Low NO<sub>x</sub> burners and Over Fire Air shall be adopted besides installation of SCR/SNCR systems wherever needed by the year 2022;

WHEREAS, electricity is cleanest form of energy which helps in mitigating house hold air pollution which is matter of concern;

WHEREAS, there is need to provide electricity supply to people who do not yet have access to it;

WHEREAS, taking into consideration the technical challenges and time requirements for installation of FGD and other technologies to meet the new emission limits, the MoEF&CC vide its letter F. No. Q-15017/40/2007-CPW dated 07.12.2017 has directed CPCB to direct all the thermal power plants to ensure compliance with the norms laid down in the 07.12.2015 notification in accordance with the revised Plan submitted by the Ministry of Power letter dated 13.10.2017 as well as NOx by 2022;

WHEREAS, the Ministry of Environment, Forest & Climate Change, Government of India, vide Notifications No. S. O. 157 (E) of 27.02.1996 and S. O. 730 (E) dated 10.07.2002, has delegated the powers vested under Section 5 of the Environment (Protection) Act, 1986 (29 of 1986) to the Chairman, Central Pollution Control Board, to issue directions to any industry or any local body or any other authority for violations of the standards and rules notified under the Environment (Protection) Rules, 1986 and amendment thereof.

NOW, THEREFORE, taking into consideration all material facts including environmental concerns and ensuring stability of power supply and need for phasing the implementation, in exercise of powers vested under Section 5 of the Environment (Protection) Act, 1986, following directions are issued to M/s Bokaro A Thermal Power Station:

- i. That plant shall install/retrofit Electrostatic Precipitators ( ESP) by June 30, 2022 in Unit 1 so as to comply PM emission limit
- ii. That plant shall install FGD by June 30, 2022 in Unit 1 so as to comply SO<sub>2</sub> emission limit
- iii. That plant shall take immediate measure like installation of low NOx burners, providing Over Fire Air ( OFA) etc. and achieve progressive reduction so as to comply NOx emission limit by the year 2022

The time line mentioned above (i to iii) for compliance of PM, SO<sub>2</sub> & NOx emission limits shall be reviewed by CPCB within a period of three months and shall be brought down further considering the location specificity of the plant such as critical polluted area/ closeness to habitation/ urban area.

The time line for compliance of water consumption limit shall also be finalised in consultation of plants

M/s Bokaro A Thermal Power Station shall ensure compliance of directions mentioned above (i to iii) failing which action will be taken under the appropriate provisions of the Environment (Protection) Act, 1986.

  
(A.K. Mehta)  
Chairman

hcg

**Copy to:**

1. The Chairman  
Jharkhand State Pollution Control Board  
T.A. Bldg., HEC, P. O.  
Dhurwa, Ranchi-834 004 (Jharkhand)
2. The Joint Secretary (CP Division)  
Ministry of Environment, Forests and Climate Change  
Prithvi Wing, 2nd Floor, Room No. 216  
Indira Paryavaran Bhawan, Aliganj,  
Jor Bagh Road, New Delhi - 110003
3. The Joint Secretary (Thermal)  
Ministry of Power  
Shram Shakti Bhawan, Rafi Marg  
New Delhi
4. The Regional Director,  
Central Pollution Control Board  
Southend Conclave, Block 502, 5th & 6th Floor  
1582, Rajdanga Main Road  
Kolkata - 700 107
5. The Divisional Head - IT, CPCB



(A. Sudhakar)  
Member Secretary



SPEED POST

B-33014/07/2017-18/IPC-II/TPP/

December 11, 2017

To

M/s Chandrapura Thermal Power Station  
Domodar Valley Corporation  
Chandrapura, Dist: Bokaro-825303;  
Jharkhand

**Sub: Directions under Section 5 of the Environment (Protection) Act, 1986 regarding compliance of emission limit notified vide notification No.S.O.3305 (E) dated 07.12.2015 - reg.**

WHEREAS, taking into consideration pollution from thermal power plants, Ministry of Environment, Forest & Climate Change had issued notification in the year 1984 laying out standards for thermal power plants. Further, the stack height regulation was notified in the year 1989 and effluent standard for thermal power plants was notified in the year 1986. The revised temperature limit of discharge of cooling water from the plants was notified in the year 1999 and thereafter use of beneficiated coal in the plants was issued in June 2002. The fly ash utilization notification was also issued On 14th September, 1999 and amended in the year 2003 and 2009. Thereafter, MoEF&CC vide Notification No. S.O.3305(E) dated 07.12.2015 has amended emission limit for particulate matter and notified new limits for Sulphur dioxide (SO<sub>2</sub>), Oxides of Nitrogen (NO<sub>x</sub>) and mercury emission, and water consumption limit for coal/lignite based thermal power plants. As per the notification dated 07.12.2015, thermal power plants are required to achieve the notified limit within two years from the date of the notification i.e. by 07.12.2017;

WHEREAS, with the implementation of the amendment dated 07.12.2015, it is expected that there would be reduction in emission of PM, Sulphur dioxide and oxide of Nitrogen, which in turn will help in improvement in Ambient Air Quality in and around thermal power plants, besides reduction of mercury emission and water use in the thermal power plants will reduce;

WHEREAS, in the meeting on Coal Washeries (Environment & Forest Clearances) and Emission Norms for Thermal Power Plants chaired by the Hon'ble Minister of Environment, Forest & Climate Change and Minister of Power, Coal & Renewable Energy on June 08, 2016, it was decided that a committee comprising representatives from MoEF & CC, Ministry of Power (MoP), Central electricity Authority (CEA), Ministry of Coal (MoC), Power Grid Corporation of India Limited (PGCI) and Central Pollution Control Board (CPCB) may be constituted to look into the all issues related to implementation of norms;

WHEREAS, following decisions were taken in the meeting:

1. MoP/CEA shall submit action plan by December 2016 for phasing out of the power plants commissioned before December, 2003.
2. MoP / CEA shall submit action plan by December, 2016 in respect of power plants commissioned during January, 2004 to December, 2016 indicating unit wise retrofit / renovation for each power plant. The implementation of action plan shall be taken up in backward manner starting from the plants commissioned in the 2015 and the shall be completed by 15.08.2022
3. MoP and CEA shall coordinate with each State Public Sector Undertakings separately for submission of action plan by December, 2016 for all the power plants.

WHEREAS, it was further decided that MoP shall take action for installation of Flue gas Desulphurisation (FGD) if needed to achieve prescribed SO<sub>2</sub> norms based on the SO<sub>2</sub> emission levels from power plants;

WHEREAS, it was also pointed out that NO<sub>x</sub> control technology in case of Indian coal is not established. Selective Catalytic Reduction (SCR) technology is used for NO<sub>x</sub> control, however, its feasibility for Indian coal needs to be established. MoP suggested that Pilot studies may be taken up in two plants and based on the results, further action plan to be drawn regarding retrofitting of SCR in plants to achieve prescribed NO<sub>x</sub> norms;

WHEREAS, the MoP constituted a committee under the Chairmanship of Chairman, Central Electricity Authority (CEA) on 21.09.2016 to prepare an action plan for implementation of new emission limits;

WHEREAS, to ensure compliance of the new emission norms the MOEF&CC convened a meeting on 23.05.2017 in which CEA, NTPC and the Central Pollution Control Board participated;

WHEREAS, the MOEF&CC received a letter from Secretary Ministry of Power *vide* their D.O. letter No. FU-1/2016-IPC dated 30<sup>th</sup> June, 2017 indicating the concerns of various thermal power plants in the country with regard to the compliance with the new emission norms for the thermal power plants notified on 7.12.2015 particularly w.r.t. Particulate Matter (PM), Sulphur dioxide (SO<sub>2</sub>) & Oxides of Nitrogen (NO<sub>x</sub>);

WHEREAS, it was noted that out of present 196667 MW installed capacity, about 60 % capacity (1,15,214 MW) meets the new PM norms with existing ESP installations. Remaining capacity of 64,334 MW which does not meet the new environmental norms regarding PM, requiring retrofitting additional fields in Electrostatic Precipitator (ESP)/replacement of ESP in existing plants to meet the new emission norms of PM;

WHEREAS, Ministry of Power after consultation with Central electricity Authority informed that retrofitting additional fields in ESP/replacement of ESP in existing plants will need complete shutdown of 4-6 months for each unit;

WHEREAS, in order to meet SO<sub>2</sub> emission norms, FGD system shall be required to be installed in all plants. MoP informed that about 30-36 months required for design & engineering, approvals, funds arrangements, tendering, erection and commissioning of FGD. Besides, planned shutdown will be required as all plants cannot be shut down simultaneously. Another challenge highlighted for installation of FGD was availability of technologies/suppliers. In addition, issues relating to availability of good quality lime stone for operation of FGD and disposal of Gypsum to run the FGD in existing plants were also taken note of;

WHEREAS, the standard of 300 & 100 mg/NM<sup>3</sup> would require installation of Selective Non Catalytic Reduction (SNCR) or Selective Non Catalytic Reduction (SCR). While these technologies are established globally, these are not established for Indian Coal, which has high ash content. Therefore, it was decided to engage various technology vendors to run pilots at NTPC stations to validate technology of SNCR/SCR system for Indian coal;

WHEREAS, the Ministry of Power in the letter dated 30.06.2017 enclosed the report outlining the plan of action for implementation of the new norms keeping in mind the techno-economic feasibility and ensuring availability of power to all at affordable cost without any disruption;

WHEREAS, as per the phasing plan proposed by MOP after consultation with CEA and Regional Power Committees, out of the installed capacity of 1, 87,162 MW ( as on December, 2016), 8217 MW have been identified for retirement/already retired. Further, 12,974 MW of capacity already have either CFBC boilers or FGDs.

WHEREAS, a phasing plan was proposed for the balance 165971 MW of coal based thermal capacity for achieving compliance with 145977 MW capacity proposing installation of FGDs within a period of 7 years to be undertaken in a phased manner. About 3205 MW of coal based capacity was stated to be compliant with revised norms of SO<sub>2</sub> emission;

WHEREAS, it was further noted that approximately about 16789 MW would not be able to install FGDs due to various constraints which include lack of space, etc.;

WHEREAS, CEA has worked out the requirement of capacity of coal based thermal power plants including hydro, wind, solar, gas based units to meet the estimated peak demand of 225 GW in 2021-22;

WHEREAS, MoP suggested that the compliance period of PM for the plants installing FGD may be kept same as per the FGD phasing plan;

WHEREAS, it was requested that for implementation of NO<sub>x</sub> norms in the plants installed before 31.12.2003 a period of three years may be permitted to achieve specified standards of 600 mg/Nm<sup>3</sup>. For other plants a relaxation of 600 mg/Nm<sup>3</sup> in place of 300 and 100 mg/Nm<sup>3</sup> for a period of 3 years was also requested;

WHEREAS, taking into account the issues/concerns raised by the MoP and the sensitivity involved in the matter as it relates to general public of the country, the Ministry undertook detailed analysis of each of the issues in the meetings held on 06.07.2017, 27.07.2017, 11.08.2017 and 01.09.2017. These meetings were also attended by the various stakeholders including Ministry of Power, CEA, NTPC etc.;

WHEREAS, MOEF & CC in the meeting with MoP, CEA, NTPC & CPCB etc. held on September 1, 2017 decided that the action plan submitted by MoP for 7 years i.e. up to 2024 was too long and it should instead commence from 2018 and implemented by 2022 with respect to all pollutants. It was further suggested that action plan should be revised prioritising the plants located in critically polluted area /close to habitation /urban area. Based on the decisions taken in the meeting Ministry of Power vide letter No. FU-1/2017-IPC dated 13.10.2017 submitted the revised action plan, to implement/phasing FGD installation/ ESP upgradation to meet new emission norms for thermal power plants;

WHEREAS, as per the revised plan submitted by the MoP vide letter dated 13.10.2017, 650 units comprising 196667 MW need to meet the new emission limits. Out of 650 units, FGD will be installed to achieve the emission limit of SO<sub>2</sub> by the year 2022 in all 415 units comprising 161522 MW (01 unit by 2018, 08 units by 2019, and 55 units by 2020, 172 units by 2021 and 178 units by 2022, for 01 units with 150 MW capacity plan is not received). Remaining 235 units comprised of 35145 MW either complying with SO<sub>2</sub> emission limits or planned for phasing out;

WHEREAS, ESP upgradation to achieve emission limit of particulate matter will be completed by the year 2022 in PM for 231 units comprising of 65925 MW capacity out of 650 units (01 unit by 2018, 02 units by 2019, 28 units by 2020, 97 units by 2021 and 94 units by 2022, for 09 units of 1400 MW capacity plan by 2022);

WHEREAS, with regard to compliance of emission limit of NO<sub>x</sub>, it is suggested that pre combustion modification such as in situ modification in boiler, installation of Low NO<sub>x</sub> burners and Over Fire Air shall be adopted besides installation of SCR/SNCR systems wherever needed by the year 2022;

WHEREAS, electricity is cleanest form of energy which helps in mitigating house hold air pollution which is matter of concern;

WHEREAS, there is need to provide electricity supply to people who do not yet have access to it;



WHEREAS, taking into consideration the technical challenges and time requirements for installation of FGD and other technologies to meet the new emission limits, the MoEF&CC vide its letter F. No. Q-15017/40/2007-CPW dated 07.12.2017 has directed CPCB to direct all the thermal power plants to ensure compliance with the norms laid down in the 07.12.2015 notification in accordance with the revised Plan submitted by the Ministry of Power letter dated 13.10.2017 as well as NOx by 2022;

WHEREAS, the Ministry of Environment, Forest & Climate Change, Government of India, vide Notifications No. S. O. 157 (E) of 27.02.1996 and S. O. 730 (E) dated 10.07.2002, has delegated the powers vested under Section 5 of the Environment (Protection) Act, 1986 (29 of 1986) to the Chairman, Central Pollution Control Board, to issue directions to any industry or any local body or any other authority for violations of the standards and rules notified under the Environment (Protection) Rules, 1986 and amendment thereof.

NOW, THEREFORE, taking into consideration all material facts including environmental concerns and ensuring stability of power supply and need for phasing the implementation, in exercise of powers vested under Section 5 of the Environment (Protection) Act, 1986, following directions are issued to M/s Chandrapura Thermal Power Station:

- i. That plant shall install/retrofit Electrostatic Precipitators ( ESP) so as to comply PM emission limit immediately
- ii. That plant shall install FGD by December 31, 2022 in Unit 7 & 8 so as to comply SO<sub>2</sub> emission limit
- iii. That plant shall take immediate measure like installation of low NOx burners, providing Over Fire Air ( OFA) etc. and achieve progressive reduction so as to comply NOx emission limit by the year 2022

The time line mentioned above (i to iii) for compliance of PM, SO<sub>2</sub> & NOx emission limits shall be reviewed by CPCB within a period of three months and shall be brought down further considering the location specificity of the plant such as critical polluted area/ closeness to habitation/ urban area.

The time line for compliance of water consumption limit shall also be finalised in consultation of plants

M/s Chandrapura Thermal Power Station shall ensure compliance of directions mentioned above (i to iii) failing which action will be taken under the appropriate provisions of the Environment (Protection) Act, 1986.

  
(A.K. Mehta)  
Chairman

hsg



**Copy to:**

1. The Chairman  
Jharkhand State Pollution Control Board  
T.A. Bldg., HEC, P. O.  
Dhurwa, Ranchi-834 004 (Jharkhand)
2. The Joint Secretary (CP Division)  
Ministry of Environment, Forests and Climate Change  
Prithvi Wing, 2nd Floor, Room No. 216  
Indira Paryavaran Bhawan, Aliganj,  
Jor Bagh Road, New Delhi - 110003
3. The Joint Secretary (Thermal)  
Ministry of Power  
Shram Shakti Bhawan, Rafi Marg  
New Delhi
4. The Regional Director,  
Central Pollution Control Board  
Southend Conclave, Block 502, 5th & 6th Floor  
1582, Rajdanga Main Road  
Kolkata - 700 107
5. The Divisional Head - IT, CPCB



(A. Sudhakar)  
Member Secretary

SPEED POST

B-33014/07/2017-18/IPC-II/TPP/

December 11, 2017

To

Bellary Thermal Power Station,  
Kuduthini, Dist. Bellary - 583115  
Karnataka

Sub: Directions under Section 5 of the Environment (Protection) Act, 1986 regarding compliance of emission limit notified vide notification No.S.O.3305 (E) dated 07.12.2015 - reg.

WHEREAS, taking into consideration pollution from thermal power plants, Ministry of Environment, Forest & Climate Change had issued notification in the year 1984 laying out standards for thermal power plants. Further, the stack height regulation was notified in the year 1989 and effluent standard for thermal power plants was notified in the year 1986. The revised temperature limit of discharge of cooling water from the plants was notified in the year 1999 and thereafter use of beneficiated coal in the plants was issued in June 2002. The fly ash utilization notification was also issued On 14th September, 1999 and amended in the year 2003 and 2009. Thereafter, MoEF&CC vide Notification No. S.O.3305(E) dated 07.12.2015 has amended emission limit for particulate matter and notified new limits for Sulphur dioxide (SO<sub>2</sub>), Oxides of Nitrogen (NO<sub>x</sub>) and mercury emission, and water consumption limit for coal/lignite based thermal power plants. As per the notification dated 07.12.2015, thermal power plants are required to achieve the notified limit within two years from the date of the notification i.e. by 07.12.2017;

WHEREAS, with the implementation of the amendment dated 07.12.2015, it is expected that there would be reduction in emission of PM, Sulphur dioxide and oxide of Nitrogen, which in turn will help in improvement in Ambient Air Quality in and around thermal power plants, besides reduction of mercury emission and water use in the thermal power plants will reduce;

WHEREAS, in the meeting on Coal Washeries (Environment & Forest Clearances) and Emission Norms for Thermal Power Plants chaired by the Hon'ble Minister of Environment, Forest & Climate Change and Minister of Power, Coal & Renewable Energy on June 08, 2016, it was decided that a committee comprising representatives from MoEF & CC, Ministry of Power (MoP), Central electricity Authority (CEA), Ministry of Coal (MoC), Power Grid Corporation of India Limited (PGCI) and Central Pollution Control Board (CPCB) may be constituted to look into the all issues related to implementation of norms;

WHEREAS, following decisions were taken in the meeting:

1. MoP/CEA shall submit action plan by December 2016 for phasing out of the power plants commissioned before December, 2003.
2. MoP / CEA shall submit action plan by December, 2016 in respect of power plants commissioned during January, 2004 to December, 2016 indicating unitwise retrofit / renovation for each power plant. The implementation of action plan shall be taken up in backward manner starting from the plants commissioned in the 2015 and the shall be completed by 15.08.2022
3. MoP and CEA shall coordinate with each State Public Sector Undertakings separately for submission of action plan by December, 2016 for all the power plants.

WHEREAS, it was further decided that MoP shall take action for installation of Flue gas Desulphurisation (FGD) if needed to achieve prescribed SO<sub>2</sub> norms based on the SO<sub>2</sub> emission levels from power plants;

WHEREAS, it was also pointed out that NO<sub>x</sub> control technology in case of Indian coal is not established. Selective Catalytic Reduction (SCR) technology is used for NO<sub>x</sub> control, however, its feasibility for Indian coal needs to be established. MoP suggested that Pilot studies may be taken up in two plants and based on the results, further action plan to be drawn regarding retrofitting of SCR in plants to achieve prescribed NO<sub>x</sub> norms;

WHEREAS, the MoP constituted a committee under the Chairmanship of Chairman, Central Electricity Authority (CEA) on 21.09.2016 to prepare an action plan for implementation of new emission limits;

WHEREAS, to ensure compliance of the new emission norms the MOEF&CC convened a meeting on 23.05.2017 in which CEA, NTPC and the Central Pollution Control Board participated;

WHEREAS, the MOEF&CC received a letter from Secretary Ministry of Power *vide* their D.O. letter No. FU-1/2016-IPC dated 30<sup>th</sup> June, 2017 indicating the concerns of various thermal power plants in the country with regard to the compliance with the new emission norms for the thermal power plants notified on 7.12.2015 particularly w.r.t. Particulate Matter (PM), Sulphur dioxide (SO<sub>2</sub>) & Oxides of Nitrogen (NO<sub>x</sub>);

WHEREAS, it was noted that out of present 196667 MW installed capacity, about 60 % capacity (1,15,214 MW) meets the new PM norms with existing ESP installations. Remaining capacity of 64,334 MW which does not meet the new environmental norms regarding PM, requiring retrofitting additional fields in Electrostatic Precipitator (ESP)/replacement of ESP in existing plants to meet the new emission norms of PM;

WHEREAS, Ministry of Power after consultation with Central electricity Authority informed that retrofitting additional fields in ESP/replacement of ESP in existing plants will need complete shutdown of 4-6 months for each unit;

WHEREAS, in order to meet SO<sub>2</sub> emission norms, FGD system shall be required to be installed in all plants. MoP informed that about 30-36 months required for design&engineering, approvals, funds arrangements, tendering, erection and commissioning of FGD. Besides, planned shutdown will be required as all plants cannot be shut down simultaneously. Another challenge highlighted for installation of FGD was availability of technologies/suppliers. In addition, issues relating to availability of good quality lime stone for operation of FGD and disposal of Gypsum to run the FGD in existing plants were also taken note of;

WHEREAS, the standard of 300 & 100 mg/NM<sup>3</sup> would require installation of Selective Non Catalytic Reduction (SNCR) or Selective Non Catalytic Reduction (SCR). While these technologies are established globally, these are not established for Indian Coal, which has high ash content. Therefore, it was decided to engage various technology vendors to run pilots at NTPC stations to validate technology of SNCR/SCR system for Indian coal;

WHEREAS, the Ministry of Power in the letter dated 30.06.2017 enclosed the report outlining the plan of action for implementation of the new norms keeping in mind the techno-economic feasibility and ensuring availability of power to all at affordable cost without any disruption;

WHEREAS, as per the phasing plan proposed by MOP after consultation with CEA and Regional Power Committees, out of the installed capacity of 1, 87,162 MW ( as on December, 2016), 8217 MW have been identified for retirement/already retired. Further, 12,974 MW of capacity already have either CFBC boilers or FGDs.

WHEREAS, a phasing plan was proposed for the balance 165971 MW of coal based thermal capacity for achieving compliance with 145977 MW capacity proposing installation of FGDs within a period of 7 years to be undertaken in a phased manner. About 3205 MW of coal based capacity was stated to be compliant with revised norms of SO<sub>2</sub> emission;

WHEREAS, it was further noted that approximately about 16789 MW would not be able to install FGDs due to various constraints which include lack of space, etc.;

WHEREAS, CEA has worked out the requirement of capacity of coal based thermal power plants including hydro, wind, solar, gas based units to meet the estimated peak demand of 225 GW in 2021-22;

WHEREAS, MoP suggested that the compliance period of PM for the plants installing FGD may be kept same as per the FGD phasing plan;

WHEREAS, it was requested that for implementation of NO<sub>x</sub> norms in the plants installed before 31.12.2003 a period of three years may be permitted to achieve specified standards of 600 mg/Nm<sup>3</sup>. For other plants a relaxation of 600 mg/Nm<sup>3</sup> in place of 300 and 100 mg/Nm<sup>3</sup> for a period of 3 years was also requested;



WHEREAS, taking into account the issues/concerns raised by the MoP and the sensitivity involved in the matter as it relates to general public of the country, the Ministry undertook detailed analysis of each of the issues in the meetings held on 06.07.2017, 27.07.2017, 11.08.2017 and 01.09.2017. These meetings were also attended by the various stakeholders including Ministry of Power, CEA, NTPC etc.;

WHEREAS, MOEF & CC in the meeting with MoP, CEA, NTPC & CPCB etc. held on September 1, 2017 decided that the action plan submitted by MoP for 7 years i.e. upto 2024 was too long and it should instead commence from 2018 and implemented by 2022 with respect to all pollutants. It was further suggested that action plan should be revised prioritising the plants located in critically polluted area /close to habitation /urban area. Based on the decisions taken in the meeting Ministry of Power vide letter No. FU-1/2017-IPC dated 13.10.2017 submitted the revised action plan, to implement/phasing FGD installation/ ESP upgradation to meet new emission norms for thermal power plants;

WHEREAS, as per the revised plan submitted by the MoP vide letter dated 13.10.2017, 650 units comprising 196667 MW need to meet the new emission limits. Out of 650 units, FGD will be installed to achieve the emission limit of SO<sub>2</sub> by the year 2022 in all 415 units comprising 161522 MW (01 unit by 2018, 08 units by 2019, and 55 units by 2020, 172 units by 2021 and 178 units by 2022, for 01 units with 150 MW capacity plan is not received). Remaining 235 units comprised of 35145 MW either complying with SO<sub>2</sub> emission limits or planned for phasing out;

WHEREAS, ESP upgradation to achieve emission limit of particulate matter will be completed by the year 2022 in PM for 231 units comprising of 65925 MW capacity out of 650 units (01 unit by 2018, 02 units by 2019, 28 units by 2020, 97 units by 2021 and 94 units by 2022, for 09 units of 1400 MW capacity plan by 2022);

WHEREAS, with regard to compliance of emission limit of NO<sub>x</sub>, it is suggested that pre combustion modification such as in situ modification in boiler, installation of Low NO<sub>x</sub> burners and Over Fire Air shall be adopted besides installation of SCR/SNCR systems wherever needed by the year 2022;

WHEREAS, electricity is cleanest form of energy which helps in mitigating household air pollution which is matter of concern;

WHEREAS, there is need to provide electricity supply to people who do not yet have access to it;

WHEREAS, taking into consideration the technical challenges and time requirements for installation of FGD and other technologies to meet the new emission limits, the MoEF&CC vide its letter F. No. Q-15017/40/2007-CPW dated 07.12.2017 has directed CPCB to direct all the thermal power plants to ensure compliance with the norms laid down in the 07.12.2015



notification in accordance with the revised Plan submitted by the Ministry of Power letter dated 13.10.2017 as well as NOx by 2022;

WHEREAS, the Ministry of Environment, Forest & Climate Change, Government of India, vide Notifications No. S. O. 157 (E) of 27.02.1996 and S. O. 730 (E) dated 10.07.2002, has delegated the powers vested under Section 5 of the Environment (Protection) Act, 1986 (29 of 1986) to the Chairman, Central Pollution Control Board, to issue directions to any industry or any local body or any other authority for violations of the standards and rules notified under the Environment (Protection) Rules, 1986 and amendment thereof.

NOW, THEREFORE, taking into consideration all material facts including environmental concerns and ensuring stability of power supply and need for phasing the implementation, in exercise of powers vested under Section 5 of the Environment (Protection) Act, 1986, following directions are issued to M/s Bellary Thermal Power Station:

- i. That plant shall meet emission limit of PM immediately by installing Electrostatic Precipitator (ESP)
- ii. That plant shall install FGD by December 31, 2020, June 30, 2021 and December 31, 2021 in Unit 1, 2 & 3 respectively so as to comply SO<sub>2</sub> emission limit
- iii. That plant shall take immediate measure like installation of low NOx burners, providing Over Fire Air (OFA) etc. and achieve progressive reduction so as to comply NOx emission limit by the year 2022

The time line mentioned above (i to iii) for compliance of PM, SO<sub>2</sub> & NOx emission limits shall be reviewed by CPCB within a period of three months and shall be brought down further considering the location specificity of the plant such as critical polluted area/ closeness to habitation/ urban area.

The time line for compliance of water consumption limit shall also be finalised in consultation of plants


M/s Bellary Thermal Power Station shall ensure compliance of directions mentioned above (i to iii) failing which action will be taken under the appropriate provisions of the Environment (Protection) Act, 1986.

  
-(A.K. Mehta)  
Chairman  


Copy to:

1. The Chairman  
Karnataka State Pollution Control Board  
6th-9th floors, Public Utility Building  
Mahatma Gandhi Road, Bangalore 560 001  
Karnataka

2. The Joint Secretary (CP Division)  
Ministry of Environment, Forests and Climate Change  
Prithvi Wing, 2nd Floor, Room No. 216  
Indira Paryavaran Bhawan, Aliganj,  
Jor Bagh Road, New Delhi - 110 003
3. The Joint Secretary (Thermal)  
Ministry of Power  
Shram Shakti Bhawan, Rafi Marg  
New Delhi
4. The Regional Director,  
Central Pollution Control Board  
1st & 2nd Floors, Nisarga Bhavan, A-Block,  
Thimmaiah Main Road, 7th D Cross,  
Shivanagar, Bengaluru - 560 079
5. The Divisional Head - IT, CPCB



(A. Sudhakar)  
Member Secretary

SPEED POST

B-33014/07/2017-18/IPC-II/TPP/

December 14, 2017

To

M/s Raichur Thermal Power Station  
Karnataka Power Corporation  
Dist: Raichur-584 170; Karnataka

**Sub: Directions under Section 5 of the Environment (Protection) Act, 1986 regarding compliance of emission limit notified vide notification No.S.O.3305 (E) dated 07.12.2015 - reg.**

WHEREAS, taking into consideration pollution from thermal power plants, Ministry of Environment, Forest & Climate Change had issued notification in the year 1984 laying out standards for thermal power plants. Further, the stackheight regulation was notified in the year 1989 and effluent standard for thermal power plants was notified in the year 1986. The revised temperature limit of discharge of cooling water from the plants was notified in the year 1999 and thereafter use of beneficiated coal in the plants was issued in June 2002. The fly ash utilization notification was also issued on 14th September, 1999 and amended in the year 2003 and 2009. Thereafter, MoEF&CC vide Notification No.S.O.3305(E) dated 07.12.2015 has amended emission limit for particulate matter and notified new limits for Sulphur dioxide (SO<sub>2</sub>), Oxides of Nitrogen (NO<sub>x</sub>) and mercury emission, and water consumption limit for coal/lignite based thermal power plants. As per the notification dated 07.12.2015, thermal power plants are required to achieve the notified limit within two years from the date of the notification i.e. by 07.12.2017;

WHEREAS, with the implementation of the amendment dated 07.12.2015, it is expected that there would be reduction in emission of PM, Sulphur dioxide and oxide of Nitrogen, which in turn will help in improvement in Ambient Air Quality in and around thermal power plants, besides reduction of mercury emission and water use in the thermal power plants will reduce;

WHEREAS, in the meeting on Coal Washeries (Environment & Forest Clearances) and Emission Norms for Thermal Power Plants chaired by the Hon'ble Minister of Environment, Forest & Climate Change and Minister of Power, Coal & Renewable Energy on June 08, 2016, it was decided that a committee comprising representatives from MoEF&CC, Ministry of Power (MoP), Central electricity Authority (CEA), Ministry of Coal (MoC), Power Grid Corporation of India Limited (PGCI) and Central Pollution Control Board (CPCB) may be constituted to look into the all issues related to implementation of norms;

WHEREAS, following decisions were taken in the meeting:

1. MoP/CEA shall submit action plan by December 2016 for phasing out of the power plants commissioned before December, 2003.
2. MoP / CEA shall submit action plan by December, 2016 in respect of power plants commissioned during January, 2004 to December, 2016 indicating unitwise retrofit / renovation for each power plant. The implementation of action plan shall be taken up in backward manner starting from the plants commissioned in the 2015 and the shall be completed by 15.08.2022
3. MoP and CEA shall coordinate with each State / Public Sector Undertakings separately for submission of action plan by December, 2016 for all the power plants.

WHEREAS, it was further decided that MoP shall take action for installation of Flue gas Desulphurisation (FGD) if needed to achieve prescribed SO<sub>2</sub> norms based on the SO<sub>2</sub> emission levels from power plants;

WHEREAS, it was also pointed out that NO<sub>x</sub> control technology in case of Indian coal is not established. Selective Catalytic Reduction (SCR) technology is used for NO<sub>x</sub> control, however, its feasibility for Indian coal needs to be established. MoP suggested that Pilot studies may be taken up in two plants and based on the results, further action plan to be drawn regarding retrofitting of SCR in plants to achieve prescribed NO<sub>x</sub> norms;

WHEREAS, the MoP constituted a committee under the Chairmanship of Chairman, Central Electricity Authority (CEA) on 21.09.2016 to prepare an action plan for implementation of new emission limits;

WHEREAS, to ensure compliance of the new emission norms the MOEF&CC convened a meeting on 23.05.2017 in which CEA, NTPC and the Central Pollution Control Board participated;

WHEREAS, the MOEF&CC received a letter from Secretary Ministry of Power *vide* their D.O. letter No. FU-1/2016-IPC dated 30<sup>th</sup> June, 2017 indicating the concerns of various thermal power plants in the country with regard to the compliance with the new emission norms for the thermal power plants notified on 7.12.2015 particularly w.r.t. Particulate Matter (PM), Sulphur dioxide (SO<sub>2</sub>) & Oxides of Nitrogen (NO<sub>x</sub>);

WHEREAS, it was noted that out of present 196667 MW installed capacity, about 60 % capacity (1,15,214 MW) meets the new PM norms with existing ESP installations. Remaining capacity of 64,334 MW which does not meet the new environmental norms regarding PM, requiring retrofitting additional fields in Electrostatic Precipitator (ESP)/replacement of ESP in existing plants to meet the new emission norms of PM;

WHEREAS, Ministry of Power after consultation with Central electricity Authority informed that retrofitting additional fields in ESP/replacement of ESP in existing plants will need complete shutdown of 4-6 months for each unit;

WHEREAS, in order to meet SO<sub>2</sub> emission norms, FGD system shall be required to be installed in all plants. MoP informed that about 30-36 months required for design&engineering, approvals, funds arrangements, tendering, erection and commissioning of FGD. Besides, planned shutdown will be required as all plants cannot be shut down simultaneously. Another challenge highlighted for installation of FGD was availability of technologies/suppliers. In addition, issues relating to availability of good quality lime stone for operation of FGD and disposal of Gypsum to run the FGD in existing/plants were also taken note of;

WHEREAS, the standard of 300 & 100 mg/NM<sup>3</sup> would require installation of Selective Non Catalytic Reduction (SNCR) or Selective Non Catalytic Reduction (SCR). While these technologies are established globally, these are not established for Indian Coal, which has high ash content. Therefore, it was decided to engage various technology vendors to run pilots at NTPC stations to validate technology of SNCR/SCR system for Indian coal;

WHEREAS, the Ministry of Power in the letter dated 30.06.2017 enclosed the report outlining the plan of action for implementation of the new norms keeping in mind the techno-economic feasibility and ensuring availability of power to all at affordable cost without any disruption;

WHEREAS, as per the phasing plan proposed by MOP after consultation with CEA and Regional Power Committees, out of the installed capacity of 1, 87,162 MW ( as on December, 2016), 8217 MW have been identified for retirement/already retired. Further, 12,974 MW of capacity already have either CFBC boilers or FGDs.

WHEREAS, a phasing plan was proposed for the balance 165971 MW of coal based thermal capacity for achieving compliance with 145977 MW capacity proposing installation of FGDs within a period of 7 years to be undertaken in a phased manner. About 3205 MW of coal based capacity was stated to be compliant with revised norms of SO<sub>2</sub> emission;

WHEREAS, it was further noted that approximately about 16789 MW would not be able to install FGDs due to various constraints which include lack of space, etc.;

WHEREAS, CEA has worked out the requirement of capacity of coal based thermal power plants including hydro, wind, solar, gas based units to meet the estimated peak demand of 225 GW in 2021-22;

WHEREAS, MoP suggested that the compliance period of PM for the plants installing FGD may be kept same as per the FGD phasing plan;

WHEREAS, it was requested that for implementation of NO<sub>x</sub> norms in the plants installed before 31.12.2003 a period of three years may be permitted to achieve specified standards of 600 mg/Nm<sup>3</sup>. For other plants a relaxation of 600 mg/Nm<sup>3</sup> in place of 300 and 100 mg/Nm<sup>3</sup> for a period of 3 years was also requested;



WHEREAS, taking into account the issues/concerns raised by the MoP and the sensitivity involved in the matter as it relates to general public of the country, the Ministry undertook detailed analysis of each of the issues in the meetings held on 06.07.2017, 27.07.2017, 11.08.2017 and 01.09.2017. These meetings were also attended by the various stakeholders including Ministry of Power, CEA, NTPC etc.;

WHEREAS, MOEF & CC in the meeting with MoP, CEA, NTPC & CPCB etc. held on September 1, 2017 decided that the action plan submitted by MoP for 7 years i.e. upto 2024 was too long and it should instead commence from 2018 and implemented by 2022 with respect to all pollutants. It was further suggested that action plan should be revised prioritising the plants located in critically polluted area /close to habitation /urban area. Based on the decisions taken in the meeting Ministry of Power vide letter No. FU-1/2017-IPC dated 13.10.2017 submitted the revised action plan, to implement/phasing FGD installation/ ESP upgradation to meet new emission norms for thermal power plants;

WHEREAS, as per the revised plan submitted by the MoP vide letter dated 13.10.2017, 650 units comprising 196667 MW need to meet the new emission limits. Out of 650 units, FGD will be installed to achieve the emission limit of SO<sub>2</sub> by the year 2022 in all 415 units comprising 161522 MW (01 unit by 2018, 08 units by 2019, and 55 units by 2020, 172 units by 2021 and 178 units by 2022, for 01 units with 150 MW capacity plan is not received). Remaining 235 units comprised of 35145 MW either complying with SO<sub>2</sub> emission limits or planned for phasing out;

WHEREAS, ESP upgradation to achieve emission limit of particulate matter will be completed by the year 2022 in PM for 231 units comprising of 65925 MW capacity out of 650 units (01 unit by 2018, 02 units by 2019, 28 units by 2020, 97 units by 2021 and 94 units by 2022, for 09 units of 1400 MW capacity plan by 2022);

WHEREAS, with regard to compliance of emission limit of NO<sub>x</sub>, it is suggested that pre combustion modification such as in situ modification in boiler, installation of Low NO<sub>x</sub> burners and Over Fire Air shall be adopted besides installation of SCR/SNCR systems wherever needed by the year 2022;

WHEREAS, electricity is cleanest form of energy which helps in mitigating-house hold air pollution which is matter of concern;

WHEREAS, there is need to provide electricity supply to people who do not yet have access to it;

WHEREAS, taking into consideration the technical challenges and time requirements for installation of FGD and other technologies to meet the new emission limits, the MoEF&CC vide its letter F. No. Q-15017/40/2007-CPW dated 07.12.2017 has directed CPCB to direct all the thermal power plants to ensure compliance with the norms laid down in the 07.12.2015

notification in accordance with the revised Plan submitted by the Ministry of Power letter dated 13.10.2017 as well as NOx by 2022;

WHEREAS, the Ministry of Environment, Forest & Climate Change , Government of India, vide Notifications No. S. O. 157 (E) of 27.02.1996 and S. O. 730 (E) dated 10.07.2002, has delegated the powers vested under Section 5 of the Environment (Protection) Act, 1986 (29 of 1986) to the Chairman, Central Pollution Control Board, to issue directions to any industry or any local body or any other authority for violations of the standards and rules notified under the Environment (Protection) Rules, 1986 and amendment thereof.

NOW, THEREFORE, taking into consideration all material facts including environmental concerns and ensuring stability of power supply and need for phasing the implementation, in exercise of powers vested under Section 5 of the Environment (Protection) Act, 1986, following directions are issued to M/s Raichur Thermal Power Station, Karnataka Power Corporation:

- i. That plant shall install/retrofit Electrostatic Precipitators ( ESP) by March 31, 2021, June 30, 2021, September 30, 2021, December 31, 2021, March 31, 2022, June 30, 2022, September 30, 2022 & December 31, 2022 in unit 1,2,3,4,5,6,7 & 8 respectively so as to comply PM emission limit
- ii. That plant shall install FGD by March 31, 2021, June 30, 2021, September 30, 2021, December 31, 2021, March 31, 2022, June 30, 2022, September 30, 2022 & December 31, 2022 in unit 1,2,3,4,5,6,7 & 8 respectively so as to comply SO2 emission limit
- iii. That plant shall take immediate measure like installation of low NOx burners, providing Over Fire Air ( OFA) etc. and achieve progressive reduction so as to comply NOx emission limit by the year 2022

The time line mentioned above (i to iii) for compliance of PM, SO<sub>2</sub> & NOx emission limits shall be reviewed by CPCB within a period of three months and shall be brought down further considering the location specificity of the plant such as critical polluted area/ closeness to habitation/ urban area.


The time line for compliance of water consumption limit shall also be finalised in consultation of plants

M/s Raichur Thermal Power Station, Karnataka Power Corporation: shall ensure compliance of directions mentioned above (i to iii) failing which action will be taken under the appropriate provisions of the Environment (Protection) Act, 1986.

  
(A.K. Mehta)  
Chairman  


Copy to:

1. The Chairman  
Karnataka State Pollution Control Board  
6th-9th floors, Public Utility Building  
Mahatma Gandhi Road, Bangalore 560 001  
Karnataka
2. The Addl. Secretary (CP Division)  
Ministry of Environment, Forests and Climate Change  
Prithvi Wing, 2nd Floor, Room No. 216  
Indira Paryavaran Bhawan, Aliganj,  
Jor Bagh Road, New Delhi - 110003
3. The Joint Secretary  
Ministry of power  
Shashtri Bhawan, Rafi Marg  
New Delhi
4. The Regional Director,  
Central Pollution Control Board  
Regional Directorate (South)  
6, West of Cord road,  
II Stage, Rajajinagar,  
Bangalore-560 086
- ✓ 5. The Divisional Head - IT, CPCB

  
(A. Sudhakar)  
Member Secretary



SPEED POST

B-33014/07/2017-18/IPC-II/TPP/

December 11, 2017

To

Yermarus Thermal Power Station  
Yegnur, Dist. Rajchur- 584134,  
Karnataka

Sub: Directions under Section 5 of the Environment (Protection) Act, 1986 regarding compliance of emission limit notified vide notification No.S.O.3305 (E) dated 07.12.2015 - reg.

WHEREAS, taking into consideration pollution from thermal power plants, Ministry of Environment, Forest & Climate Change had issued notification in the year 1984 laying out standards for thermal power plants. Further, the stack height regulation was notified in the year 1989 and effluent standard for thermal power plants was notified in the year 1986. The revised temperature limit of discharge of cooling water from the plants was notified in the year 1999 and thereafter use of beneficiated coal in the plants was issued in June 2002. The fly ash utilization notification was also issued on 14th September, 1999 and amended in the year 2003 and 2009. Thereafter, MoEF&CC vide Notification No. S.O.3305(E) dated 07.12.2015 has amended emission limit for particulate matter and notified new limits for Sulphur dioxide (SO<sub>2</sub>), Oxides of Nitrogen (NO<sub>x</sub>) and mercury emission, and water consumption limit for coal/lignite based thermal power plants. As per the notification dated 07.12.2015, thermal power plants are required to achieve the notified limit within two years from the date of the notification i.e. by 07.12.2017;

WHEREAS, with the implementation of the amendment dated 07.12.2015, it is expected that there would be reduction in emission of PM, Sulphur dioxide and oxide of Nitrogen, which in turn will help in improvement in Ambient Air Quality in and around thermal power plants, besides reduction of mercury emission and water use in the thermal power plants will reduce;

WHEREAS, in the meeting on Coal Washeries (Environment & Forest Clearances) and Emission Norms for Thermal Power Plants chaired by the Hon'ble Minister of Environment, Forest & Climate Change and Minister of Power, Coal & Renewable Energy on June 08, 2016, it was decided that a committee comprising representatives from MoEF & CC, Ministry of Power (MoP), Central electricity Authority (CEA), Ministry of Coal (MoC), Power Grid Corporation of India Limited (PGCI) and Central Pollution Control Board (CPCB) may be constituted to look into the all issues related to implementation of norms;

WHEREAS, following decisions were taken in the meeting:

1. MoP/CEA shall submit action plan by December 2016 for phasing out of the power plants commissioned before December, 2003.
2. MoP / CEA shall submit action plan by December, 2016 in respect of power plants commissioned during January, 2004 to December, 2016 indicating unitwise retrofit / renovation for each power plant. The implementation of action plan shall be taken up in backward manner starting from the plants commissioned in the 2015 and the shall be completed by 15.08.2022
3. MoP and CEA shall coordinate with each State Public Sector Undertakings separately for submission of action plan by December, 2016 for all the power plants.

WHEREAS, it was further decided that MoP shall take action for installation of Flue gas Desulphurisation (FGD) if needed to achieve prescribed SO<sub>2</sub> norms based on the SO<sub>2</sub> emission levels from power plants;

WHEREAS, it was also pointed out that NO<sub>x</sub> control technology in case of Indian coal is not established. Selective Catalytic Reduction (SCR) technology is used for NO<sub>x</sub> control, however, its feasibility for Indian coal needs to be established. MoP suggested that Pilot studies may be taken up in two plants and based on the results, further action plan to be drawn regarding retrofitting of SCR in plants to achieve prescribed NO<sub>x</sub> norms;

WHEREAS, the MoP constituted a committee under the Chairmanship of Chairman, Central Electricity Authority (CEA) on 21.09.2016 to prepare an action plan for implementation of new emission limits;

WHEREAS, to ensure compliance of the new emission norms the MOEF&CC convened a meeting on 23.05.2017 in which CEA, NTPC and the Central Pollution Control Board participated;

WHEREAS, the MOEF&CC received a letter from Secretary Ministry of Power *vide* their D.O. letter No. FU-1/2016-IPC dated 30<sup>th</sup> June, 2017 indicating the concerns of various thermal power plants in the country with regard to the compliance with the new emission norms for the thermal power plants notified on 7.12.2015 particularly w.r.t. Particulate Matter (PM), Sulphur dioxide (SO<sub>2</sub>) & Oxides of Nitrogen (NO<sub>x</sub>);

WHEREAS, it was noted that out of present 196667 MW installed capacity, about 60 % capacity (1,15,214 MW) meets the new PM norms with existing ESP installations. Remaining capacity of 64,334 MW which does not meet the new environmental norms regarding PM, requiring retrofitting additional fields in Electrostatic Precipitator (ESP)/replacement of ESP in existing plants to meet the new emission norms of PM;

WHEREAS, Ministry of Power after consultation with Central electricity Authority informed that retrofitting additional fields in ESP/replacement of ESP in existing plants will need complete shutdown of 4-6 months for each unit;



WHEREAS, in order to meet SO<sub>2</sub> emission norms, FGD system shall be required to be installed in all plants. MoP informed that about 30-36 months required for design&engineering, approvals, funds arrangements, tendering, erection and commissioning of FGD. Besides, planned shutdown will be required as all plants cannot be shut down simultaneously. Another challenge highlighted for installation of FGD was availability of technologies/suppliers. In addition, issues relating to availability of good quality lime stone for operation of FGD and disposal of Gypsum to run the FGD in existing plants were also taken note of;

WHEREAS, the standard of 300 & 100 mg/NM<sup>3</sup> would require installation of Selective Non Catalytic Reduction (SNCR) or Selective Non Catalytic Reduction (SCR). While these technologies are established globally, these are not established for Indian Coal, which has high ash content. Therefore, it was decided to engage various technology vendors to run pilots at NTPC stations to validate technology of SNCR/SCR system for Indian coal;

WHEREAS, the Ministry of Power in the letter dated 30.06.2017 enclosed the report outlining the plan of action for implementation of the new norms keeping in mind the techno-economic feasibility and ensuring availability of power to all at affordable cost without any disruption;

WHEREAS, as per the phasing plan proposed by MOP after consultation with CEA and Regional Power Committees, out of the installed capacity of 1, 87,162 MW ( as on December, 2016), 8217 MW have been identified for retirement/already retired. Further, 12,974 MW of capacity already have either CFBC boilers or FGDs.

WHEREAS, a phasing plan was proposed for the balance 165971 MW of coal based thermal capacity for achieving compliance with 145977 MW capacity proposing installation of FGDs within a period of 7 years to be undertaken in a phased manner. About 3205 MW of coal based capacity was stated to be compliant with revised norms of SO<sub>2</sub> emission;

WHEREAS, it was further noted that approximately about 16789 MW would not be able to install FGDs due to various constraints which include lack of space, etc.;

WHEREAS, CEA has worked out the requirement of capacity of coal based thermal power plants including hydro, wind, solar, gas based units to meet the estimated peak demand of 225 GW in 2021-22;

WHEREAS, MoP suggested that the compliance period of PM for the plants installing FGD may be kept same as per the FGD phasing plan;

WHEREAS, it was requested that for implementation of NO<sub>x</sub> norms in the plants installed before 31.12.2003 a period of three years may be permitted to achieve specified standards of 600 mg/Nm<sup>3</sup>. For other plants a relaxation of 600 mg/Nm<sup>3</sup> in place of 300 and 100 mg/Nm<sup>3</sup> for a period of 3 years was also requested;

WHEREAS, taking into account the issues/concerns raised by the MoP and the sensitivity involved in the matter as it relates to general public of the country, the Ministry undertook detailed analysis of each of the issues in the meetings held on 06.07.2017, 27.07.2017, 11.08.2017 and 01.09.2017. These meetings were also attended by the various stakeholders including Ministry of Power, CEA, NTPC etc.;

WHEREAS, MOEF & CC in the meeting with MoP, CEA, NTPC & CPCB etc. held on September 1, 2017 decided that the action plan submitted by MoP for 7 years i.e. upto 2024 was too long and it should instead commence from 2018 and implemented by 2022 with respect to all pollutants. It was further suggested that action plan should be revised prioritising the plants located in critically polluted area /close to habitation /urban area. Based on the decisions taken in the meeting Ministry of Power vide letter No. FU-1/2017-IPC dated 13.10.2017 submitted the revised action plan, to implement/phasing FGD installation/ ESP upgradation to meet new emission norms for thermal power plants;

WHEREAS, as per the revised plan submitted by the MoP vide letter dated 13.10.2017, 650 units comprising 196667 MW need to meet the new emission limits. Out of 650 units, FGD will be installed to achieve the emission limit of SO<sub>2</sub> by the year 2022 in all 415 units comprising 161522 MW (01 unit by 2018, 08 units by 2019, and 55 units by 2020, 172 units by 2021 and 178 units by 2022, for 01 units with 150 MW capacity plan is not received). Remaining 235 units comprised of 35145 MW either complying with SO<sub>2</sub> emission limits or planned for phasing out;

WHEREAS, ESP upgradation to achieve emission limit of particulate matter will be completed by the year 2022 in PM for 231 units comprising of 65925 MW capacity out of 650 units (01 unit by 2018, 02 units by 2019, 28 units by 2020, 97 units by 2021 and 94 units by 2022, for 09 units of 1400 MW capacity plan by 2022);

WHEREAS, with regard to compliance of emission limit of NO<sub>x</sub>, it is suggested that pre combustion modification such as in situ modification in boiler, installation of Low NO<sub>x</sub> burners and Over Fire Air shall be adopted besides installation of SCR/SNCR systems wherever needed by the year 2022;

WHEREAS, electricity is cleanest form of energy which helps in mitigating house hold air pollution which is matter of concern;

WHEREAS, there is need to provide electricity supply to people who do not yet have access to it;

WHEREAS, taking into consideration the technical challenges and time requirements for installation of FGD and other technologies to meet the new emission limits, the MoEF&CC vide its letter F. No. Q-15017/40/2007-CPW dated 07.12.2017 has directed CPCB to direct all the thermal power plants to ensure compliance with the norms laid down in the 07.12.2015

notification in accordance with the revised Plan submitted by the Ministry of Power letter dated 13.10.2017 as well as NOx by 2022;

WHEREAS, the Ministry of Environment, Forest & Climate Change, Government of India, vide Notifications No. S. O. 157 (E) of 27.02.1996 and S. O. 730 (E) dated 10.07.2002, has delegated the powers vested under Section 5 of the Environment (Protection) Act, 1986 (29 of 1986) to the Chairman, Central Pollution Control Board, to issue directions to any industry or any local body or any other authority for violations of the standards and rules notified under the Environment (Protection) Rules, 1986 and amendment thereof.

NOW, THEREFORE, taking into consideration all material facts including environmental concerns and ensuring stability of power supply and need for phasing the implementation, in exercise of powers vested under Section 5 of the Environment (Protection) Act, 1986, following directions are issued to M/s Yermarus Thermal Power Station:

- i. That plant shall meet emission limit of PM by installing Electrostatic Precipitator (ESP) by December 31, 2022 in Unit 2
- ii. That plant shall install FGD by December 31, 2021 and December 31, 2022 in Unit 1 & 2 respectively so as to comply SO<sub>2</sub> emission limit
- iii. That plant shall take immediate measure like installation of low NOx burners, providing Over Fire Air (OFA) etc. and achieve progressive reduction so as to comply NOx emission limit by the year 2022

The time line mentioned above (i to iii) for compliance of PM, SO<sub>2</sub> & NOx emission limits shall be reviewed by CPCB within a period of three months and shall be brought down further considering the location specificity of the plant such as critical polluted area/ closeness to habitation/ urban area.

The time line for compliance of water consumption limit shall also be finalised in consultation of plants


M/s Yermarus Thermal Power Station shall ensure compliance of directions mentioned above (i to iii) failing which action will be taken under the appropriate provisions of the Environment (Protection) Act, 1986.

  
(A.K. Mehta)  
Chairman

Copy to:

1. The Chairman  
Karnataka State Pollution Control Board  
"Parisara Bhavan", #49, 4th & 5th Floor,  
Church Street, Bangalore 560 001

2. The Joint Secretary (CP Division)  
Ministry of Environment, Forests and Climate Change  
Prithvi Wing, 2nd Floor, Room No. 216  
Indira Paryavaran Bhawan, Aliganj,  
Jor Bagh Road, New Delhi - 110 003
3. The Joint Secretary (Thermal)  
Ministry of Power  
Shram Shakti Bhawan, Rafi Marg  
New Delhi
4. The Regional Director,  
Central Pollution Control Board  
1st & 2nd Floors, Nisarga Bhavan, A-Block,  
Thimmaiah Main Road, 7th D Cross,  
Shivanagar, Bengaluru -560 079
- ✓ 5. The Divisional Head - IT, CPCB



(A. Sudhakar)  
Member Secretary

SPEED POST

B-33014/07/2017-18/IPC-II/TPP/

December 11, 2017

To

M/s Udupi Power Corporation Ltd  
(A Subsidiary of Adani Power Ltd) Yelluru Village,  
Pilar Post Padubidri, Udupi- 574113,  
Karnataka

**Sub: Directions under Section 5 of the Environment (Protection) Act, 1986 regarding compliance of emission limit notified vide notification No.S.O.3305 (E) dated 07.12.2015 - reg.**

WHEREAS, taking into consideration pollution from thermal power plants, Ministry of Environment, Forest & Climate Change had issued notification in the year 1984 laying out standards for thermal power plants. Further, the stack height regulation was notified in the year 1989 and effluent standard for thermal power plants was notified in the year 1986. The revised temperature limit of discharge of cooling water from the plants was notified in the year 1999 and thereafter use of beneficiated coal in the plants was issued in June 2002. The fly ash utilization notification was also issued on 14th September, 1999 and amended in the year 2003 and 2009. Thereafter, MoEF&CC vide Notification No.S.O.3305 (E) dated 07.12.2015 has amended emission limit for particulate matter and notified new limits for Sulphur dioxide (SO<sub>2</sub>), Oxides of Nitrogen (NO<sub>x</sub>) and mercury emission, and water consumption limit for coal/lignite based thermal power plants. As per the notification dated 07.12.2015, thermal power plants are required to achieve the notified limit within two years from the date of the notification i.e. by 07.12.2017;

WHEREAS, with the implementation of the amendment dated 07.12.2015, it is expected that there would be reduction in emission of PM, Sulphur dioxide and oxide of Nitrogen, which in turn will help in improvement in Ambient Air Quality in and around thermal power plants, besides reduction of mercury emission and water use in the thermal power plants will reduce;

WHEREAS, in the meeting on Coal Washeries (Environment & Forest Clearances) and Emission Norms for Thermal Power Plants chaired by the Hon'ble Minister of Environment, Forest & Climate Change and Minister of Power, Coal & Renewable Energy on June 08, 2016, it was decided that a committee comprising representatives from MoEF& CC, Ministry of Power (MoP), Central electricity Authority (CEA), Ministry of Coal (MoC), Power Grid Corporation of India Limited (PGCI) and Central Pollution Control Board (CPCB) may be constituted to look into the all issues related to implementation of norms;

WHEREAS, following decisions were taken in the meeting:



1. MoP/CEA shall submit action plan by December 2016 for phasing out of the power plants commissioned before December, 2003.
2. MoP / CEA shall submit action plan by December, 2016 in respect of power plants commissioned during January, 2004 to December, 2016 indicating unitwise retrofit / renovation for each power plant. The implementation of action plan shall be taken up in backward manner starting from the plants commissioned in the 2015 and the shall be completed by 15.08.2022
3. MoP and CEA shall coordinate with each State Public Sector Undertakings separately for submission of action plan by December, 2016 for all the power plants.

WHEREAS, it was further decided that MoP shall take action for installation of Flue gas Desulphurisation (FGD) if needed to achieve prescribed SO<sub>2</sub> norms based on the SO<sub>2</sub> emission levels from power plants;

WHEREAS, it was also pointed out that NO<sub>x</sub> control technology in case of Indian coal is not established. Selective Catalytic Reduction (SCR) technology is used for NO<sub>x</sub> control, however, its feasibility for Indian coal needs to be established. MoP suggested that Pilot studies may be taken up in two plants and based on the results, further action plan to be drawn regarding retrofitting of SCR in plants to achieve prescribed NO<sub>x</sub> norms;

WHEREAS, the MoP constituted a committee under the Chairmanship of Chairman, Central Electricity Authority (CEA) on 21.09.2016 to prepare an action plan for implementation of new emission limits;

WHEREAS, to ensure compliance of the new emission norms the MOEF&CC convened a meeting on 23.05.2017 in which CEA, NTPC and the Central Pollution Control Board participated;

WHEREAS, the MOEF&CC received a letter from Secretary Ministry of Power *vide* their D.O. letter No. FU-1/2016-IPC dated 30<sup>th</sup> June, 2017 indicating the concerns of various thermal power plants in the country with regard to the compliance with the new emission norms for the thermal power plants notified on 7.12.2015 particularly w.r.t. Particulate Matter (PM), Sulphur dioxide (SO<sub>2</sub>) & Oxides of Nitrogen (NO<sub>x</sub>);

WHEREAS, it was noted that out of present 196667 MW installed capacity, about 60 % capacity (1,15,214 MW) meets the new PM norms with existing ESP installations. Remaining capacity of 64,334 MW which does not meet the new environmental norms regarding PM, requiring retrofitting additional fields in Electrostatic Precipitator (ESP)/replacement of ESP in existing plants to meet the new emission norms of PM;

WHEREAS, Ministry of Power after consultation with Central electricity Authority informed that retrofitting additional fields in ESP/replacement of ESP in existing plants will need complete shutdown of 4-6 months for each unit;

WHEREAS, in order to meet SO<sub>2</sub> emission norms, FGD system shall be required to be installed in all plants. MoP informed that about 30-36 months required for design&engineering, approvals, funds arrangements, tendering, erection and commissioning of FGD. Besides, planned shutdown will be required as all plants cannot be shut down simultaneously. Another challenge highlighted for installation of FGD was availability of technologies/suppliers. In addition, issues relating to availability of good quality lime stone for operation of FGD and disposal of Gypsum to run the FGD in existing plants were also taken note of;

WHEREAS, the standard of 300 & 100 mg/NM<sup>3</sup> would require installation of Selective Non Catalytic Reduction (SNCR) or Selective Non Catalytic Reduction (SCR). While these technologies are established globally, these are not established for Indian Coal, which has high ash content. Therefore, it was decided to engage various technology vendors to run pilots at NTPC stations to validate technology of SNCR/SCR system for Indian coal;

WHEREAS, the Ministry of Power in the letter dated 30.06.2017 enclosed the report outlining the plan of action for implementation of the new norms keeping in mind the techno-economic feasibility and ensuring availability of power to all at affordable cost without any disruption;

WHEREAS, as per the phasing plan proposed by MOP after consultation with CEA and Regional Power Committees, out of the installed capacity of 1, 87,162 MW ( as on December, 2016), 8217 MW have been identified for retirement/already retired. Further, 12,974 MW of capacity already have either CFBC boilers or FGDs.

WHEREAS, a phasing plan was proposed for the balance 165971 MW of coal based thermal capacity for achieving compliance with 145977 MW capacity proposing installation of FGDs within a period of 7 years to be undertaken in a phased manner. About 3205 MW of coal based capacity was stated to be compliant with revised norms of SO<sub>2</sub> emission;

WHEREAS, it was further noted that approximately about 16789 MW would not be able to install FGDs due to various constraints which include lack of space, etc.;

WHEREAS, CEA has worked out the requirement of capacity of coal based thermal power plants including hydro, wind, solar, gas based units to meet the estimated peak demand of 225 GW in 2021-22;

WHEREAS, MoP suggested that the compliance period of PM for the plants installing FGD may be kept same as per the FGD phasing plan;

WHEREAS, it was requested that for implementation of NO<sub>x</sub> norms in the plants installed before 31.12.2003 a period of three years may be permitted to achieve specified standards of 600 mg/Nm<sup>3</sup>. For other plants a relaxation

of 600 mg/Nm<sup>3</sup> in place of 300 and 100 mg/Nm<sup>3</sup> for a period of 3 years was also requested;

WHEREAS, taking into account the issues/concerns raised by the MoP and the sensitivity involved in the matter as it relates to general public of the country, the Ministry undertook detailed analysis of each of the issues in the meetings held on 06.07.2017, 27.07.2017, 11.08.2017 and 01.09.2017. These meetings were also attended by the various stakeholders including Ministry of Power, CEA, NTPC etc.;

WHEREAS, MOEF & CC in the meeting with MoP, CEA, NTPC & CPCB etc. held on September 1, 2017 decided that the action plan submitted by MoP for 7 years i.e. upto 2024 was too long and it should instead commence from 2018 and implemented by 2022 with respect to all pollutants. It was further suggested that action plan should be revised prioritising the plants located in critically polluted area /close to habitation /urban area. Based on the decisions taken in the meeting Ministry of Power vide letter No. FU-1/2017-IPC dated 13.10.2017 submitted the revised action plan, to implement/phasing FGD installation/ ESP upgradation to meet new emission norms for thermal power plants;

WHEREAS, as per the revised plan submitted by the MoP vide letter dated 13.10.17, 650 units comprising 196667 MW need to meet the new emission limits. Out of 650 units, FGD will be installed to achieve the emission limit of SO<sub>2</sub> by the year 2022 in all 415 units comprising 161522 MW (01 unit by 2018, 08 units by 2019, and 55 units by 2020, 172 units by 2021 and 178 units by 2022, for 01 units with 150 MW capacity plan is not received). Remaining 235 units comprised of 35145 MW either complying with SO<sub>2</sub> emission limits or planned for phasing out;

WHEREAS, ESP upgradation to achieve emission limit of particulate matter will be completed by the year 2022 in PM for 231 units comprising of 65925 MW capacity out of 650 units (01 unit by 2018, 02 units by 2019, 28 units by 2020, 97 units by 2021 and 94 units by 2022, for 09 units of 1400 MW capacity plan by 2022);

WHEREAS, with regard to compliance of emission limit of NO<sub>x</sub>, it is suggested that pre combustion modification such as in situ modification in boiler, installation of Low NO<sub>x</sub> burners and Over Fire Air shall be adopted besides installation of SCR/SNCR systems wherever needed by the year 2022;

WHEREAS, electricity is cleanest form of energy which helps in mitigating house hold air pollution which is matter of concern;

WHEREAS, there is need to provide electricity supply to people who do not yet have access to it;

WHEREAS, taking into consideration the technical challenges and time requirements for installation of FGD and other technologies to meet the new emission limits, the MoEF&CC vide its letter F. No. Q-15017/40/2007-

CPWdated 07.12.2017 has directed CPCB to direct all the thermal power plants to ensure compliance with the norms laid down in the 07.12.2015 notification in accordance with the revised Plan submitted by the Ministry of Power letter dated 13.10.2017as well as NOx by 2022;

WHEREAS, the Ministry of Environment, Forest& Climate Change , Government of India, vide Notifications No. S. O. 157 (E) of 27.02.1996 and S. O. 730 (E) dated 10.07.2002, has delegated the powers vested under Section 5 of the Environment (Protection) Act, 1986 (29 of 1986) to the Chairman, Central Pollution Control Board, to issue directions to any industry or any local body or any other authority for violations of the standards and rules notified under the Environment (Protection) Rules, 1986 and amendment thereof.



NOW, THEREFORE, taking into consideration all material facts including environmental concerns and ensuring stability of power supply and need for phasing the implementation, in exercise of powers vested under Section 5 of the Environment (Protection) Act, 1986, following directions are issued to M/s Udupi Thermal Power Station:

- i. That plant shall meet emission limit of PM immediately by installing Electrostatic Precipitator (ESP)
- ii. That plant shall install FGD by March 31, 2022 and June 30, 2022 in Unit 1 & 2 respectively so as to comply SO<sub>2</sub> emission limit
- iii. That plant shall take immediate measure like installation of low NOx burners, providing Over Fire Air ( OFA) etc.and achieve progressive reduction so as to comply NOx emission limitby the year 2022

The time line mentioned above (i to iii) for compliance of PM, SO<sub>2</sub> & NOx emission limits shall be reviewed by CPCB within a period of three months and shall be brought down further considering the location specificity of the plant such as critical-polluted area/ closeness to habitation/ urban area.

The time line for compliance of water consumption limit shall also be finalised in consultation of plants


M/s Udupi Thermal Power Station shall ensure compliance of directions mentioned above (i to iii) failing which action will be taken under the appropriate provisions ofthe Environment (Protection) Act, 1986.

  
(A.K. Mehta)  
Chairman  


Copy to:

1. The Chairman  
Karnataka State Pollution Control Board  
"Parisara Bhavan", #49,4th & 5th Floor,  
Church Street, Bangalore 560 001

2. The Joint Secretary (CP Division)  
Ministry of Environment, Forests and Climate Change  
Prithvi Wing, 2nd Floor, Room No. 216  
Indira Paryavaran Bhawan, Aliganj,  
Jor Bagh Road, New Delhi - 110 003
3. The Joint Secretary (Thermal)  
Ministry of Power  
Shram Shakti Bhawan, Rafi Marg  
New Delhi
4. The Regional Director,  
Central Pollution Control Board  
1st & 2nd Floors, Nisarga Bhavan, A-Block,  
Thimmaiah Main Road, 7th D Cross,  
Shivanagar, Bengaluru -560 079
- ✓ 5. The Divisional Head - IT, CPCB

  
(A. Sudhakar)  
Member Secretary



SPEED POST

B-33014/07/2017-18/IPC-II/TPP/

December 11, 2017

To

M/s JSW Energy Limited (Extn TPS),  
P.B.No.9, Toranagallu, Sandur Taluk,  
Dist. Bellary- 583123  
Karnataka

Sub: Directions under Section 5 of the Environment (Protection) Act, 1986 regarding compliance of emission limit notified vide notification No.S.O.3305 (E) dated 07.12.2015 - reg.

WHEREAS, taking into consideration pollution from thermal power plants, Ministry of Environment, Forest & Climate Change had issued notification in the year 1984 laying out standards for thermal power plants. Further, the stack height regulation was notified in the year 1989 and effluent standard for thermal power plants was notified in the year 1986. The revised temperature limit of discharge of cooling water from the plants was notified in the year 1999 and thereafter use of beneficiated coal in the plants was issued in June 2002. The fly ash utilization notification was also issued On 14th September, 1999 and amended in the year 2003 and 2009. Thereafter, MoEF&CC vide Notification No.S.O.3305 (E) dated 07.12.2015 has amended emission limit for particulate matter and notified new limits for Sulphur dioxide (SO<sub>2</sub>), Oxides of Nitrogen (NO<sub>x</sub>) and mercury emission, and water consumption limit for coal/lignite based thermal power plants. As per the notification dated 07.12.2015, thermal power plants are required to achieve the notified limit within two years from the date of the notification i.e. by 07.12.2017;

WHEREAS, with the implementation of the amendment dated 07.12.2015, it is expected that there would be reduction in emission of PM, Sulphur dioxide and oxide of Nitrogen, which in turn will help in improvement in Ambient Air Quality in and around thermal power plants, besides reduction of mercury emission and water use in the thermal power plants will reduce;

WHEREAS, in the meeting on Coal Washeries (Environment & Forest Clearances) and Emission Norms for Thermal Power Plants chaired by the Hon'ble Minister of Environment, Forest & Climate Change and Minister of Power, Coal & Renewable Energy on June 08, 2016, it was decided that a committee comprising representatives from MoEF& CC, Ministry of Power (MoP), Central electricity Authority (CEA), Ministry of Coal (MoC), Power Grid Corporation of India Limited (PGCI) and Central Pollution Control Board (CPCB) may be constituted to look into the all issues related to implementation of norms;

WHEREAS, following decisions were taken in the meeting:

1. MoP/CEA shall submit action plan by December 2016 for phasing out of the power plants commissioned before December, 2003.
2. MoP / CEA shall submit action plan by December, 2016 in respect of power plants commissioned during January, 2004 to December, 2016 indicating unitwise retrofit / renovation for each power plant. The implementation of action plan shall be taken up in backward manner starting from the plants commissioned in the 2015 and the shall be completed by 15.08.2022
3. MoP and CEA shall coordinate with each State Public Sector Undertakings separately for submission of action plan by December, 2016 for all the power plants.

WHEREAS, it was further decided that MoP shall take action for installation of Flue gas Desulphurisation (FGD) if needed to achieve prescribed SO<sub>2</sub> norms based on the SO<sub>2</sub> emission levels from power plants;

WHEREAS, it was also pointed out that NO<sub>x</sub> control technology in case of Indian coal is not established. Selective Catalytic Reduction (SCR) technology is used for NO<sub>x</sub> control, however, its feasibility for Indian coal needs to be established. MoP suggested that Pilot studies may be taken up in two plants and based on the results, further action plan to be drawn regarding retrofitting of SCR in plants to achieve prescribed NO<sub>x</sub> norms;

WHEREAS, the MoP constituted a committee under the Chairmanship of Chairman, Central Electricity Authority (CEA) on 21.09.2016 to prepare an action plan for implementation of new emission limits;

WHEREAS, to ensure compliance of the new emission norms the MOEF&CC convened a meeting on 23.05.2017 in which CEA, NTPC and the Central Pollution Control Board participated;

WHEREAS, the MOEF&CC received a letter from Secretary Ministry of Power *vide* their D.O. letter No. FU-1/2016-IPC dated 30<sup>th</sup> June, 2017 indicating the concerns of various thermal power plants in the country with regard to the compliance with the new emission norms for the thermal power plants notified on 7.12.2015 particularly w.r.t. Particulate Matter (PM), Sulphur dioxide (SO<sub>2</sub>) & Oxides of Nitrogen (NO<sub>x</sub>);

WHEREAS, it was noted that out of present 196667 MW installed capacity, about 60 % capacity (1,15,214 MW) meets the new PM norms with existing ESP installations. Remaining capacity of 64,334 MW which does not meet the new environmental norms regarding PM, requiring retrofitting additional fields in Electrostatic Precipitator (ESP)/replacement of ESP in existing plants to meet the new emission norms of PM;

WHEREAS, Ministry of Power after consultation with Central electricity Authority informed that retrofitting additional fields in

ESP/replacement of ESP in existing plants will need complete shutdown of 4-6 months for each unit;

WHEREAS, in order to meet SO<sub>2</sub> emission norms, FGD system shall be required to be installed in all plants. MoP informed that about 30-36 months required for design & engineering, approvals, funds arrangements, tendering, erection and commissioning of FGD. Besides, planned shutdown will be required as all plants cannot be shut down simultaneously. Another challenge highlighted for installation of FGD was availability of technologies/suppliers. In addition, issues relating to availability of good quality lime stone for operation of FGD and disposal of Gypsum to run the FGD in existing plants were also taken note of;

WHEREAS, the standard of 300 & 100 mg/NM<sup>3</sup> would require installation of Selective Non Catalytic Reduction (SNCR) or Selective Non Catalytic Reduction (SCR). While these technologies are established globally, these are not established for Indian Coal, which has high ash content. Therefore, it was decided to engage various technology vendors to run pilots at NTPC stations to validate technology of SNCR/SCR system for Indian coal;

WHEREAS, the Ministry of Power in the letter dated 30.06.2017 enclosed the report outlining the plan of action for implementation of the new norms keeping in mind the techno-economic feasibility and ensuring availability of power to all at affordable cost without any disruption;

WHEREAS, as per the phasing plan proposed by MOP after consultation with CEA and Regional Power Committees, out of the installed capacity of 1, 87,162 MW ( as on December, 2016), 8217 MW have been identified for retirement/already retired. Further, 12,974 MW of capacity already have either CFBC boilers or FGDs.

WHEREAS, a phasing plan was proposed for the balance 165971 MW of coal based thermal capacity for achieving compliance with 145977 MW capacity proposing installation of FGDs within a period of 7 years to be undertaken in a phased manner. About 3205 MW of coal based capacity was stated to be compliant with revised norms of SO<sub>2</sub> emission;

WHEREAS, it was further noted that approximately about 16789 MW would not be able to install FGDs due to various constraints which include lack of space, etc.;

WHEREAS, CEA has worked out the requirement of capacity of coal based thermal power plants including hydro, wind, solar, gas based units to meet the estimated peak demand of 225 GW in 2021-22;

WHEREAS, MoP suggested that the compliance period of PM for the plants installing FGD may be kept same as per the FGD phasing plan;

WHEREAS, it was requested that for implementation of NO<sub>x</sub> norms in the plants installed before 31.12.2003 a period of three years may be permitted to achieve specified standards of 600 mg/Nm<sup>3</sup>. For other plants a relaxation of 600 mg/Nm<sup>3</sup> in place of 300 and 100 mg/Nm<sup>3</sup> for a period of 3 years was also requested;

WHEREAS, taking into account the issues/concerns raised by the MoP and the sensitivity involved in the matter as it relates to general public of the country, the Ministry undertook detailed analysis of each of the issues in the meetings held on 06.07.2017, 27.07.2017, 11.08.2017 and 01.09.2017. These meetings were also attended by the various stakeholders including Ministry of Power, CEA, NTPC etc.;

WHEREAS, MOEF & CC in the meeting with MoP, CEA, NTPC & CPCB etc. held on September 1, 2017 decided that the action plan submitted by MoP for 7 years i.e. up to 2024 was too long and it should instead commence from 2018 and implemented by 2022 with respect to all pollutants. It was further suggested that action plan should be revised prioritising the plants located in critically polluted area /close to habitation /urban area. Based on the decisions taken in the meeting Ministry of Power vide letter No. FU-1/2017-IPC dated 13.10.2017 submitted the revised action plan, to implement/phasing FGD installation/ ESP upgradation to meet new emission norms for thermal power plants;

WHEREAS, as per the revised plan submitted by the MoP vide letter dated 13.10.2017, 650 units comprising 196667 MW need to meet the new emission limits. Out of 650 units, FGD will be installed to achieve the emission limit of SO<sub>2</sub> by the year 2022 in all 415 units comprising 161522 MW (01 unit by 2018, 08 units by 2019, and 55 units by 2020, 172 units by 2021 and 178 units by 2022, for 01 units with 150 MW capacity plan is not received). Remaining 235 units comprised of 35145 MW either complying with SO<sub>2</sub> emission limits or planned for phasing out;

WHEREAS, ESP upgradation to achieve emission limit of particulate matter will be completed by the year 2022 in PM for 231 units comprising of 65925 MW capacity out of 650 units (01 unit by 2018, 02 units by 2019, 28 units by 2020, 97 units by 2021 and 94 units by 2022, for 09 units of 1400 MW capacity plan by 2022);

WHEREAS, with regard to compliance of emission limit of NO<sub>x</sub>, it is suggested that pre combustion modification such as in situ modification in boiler, installation of Low NO<sub>x</sub> burners and Over Fire Air shall be adopted besides installation of SCR/SNCR systems wherever needed by the year 2022;

WHEREAS, electricity is cleanest form of energy which helps in mitigating house hold air pollution which is matter of concern;

WHEREAS, there is need to provide electricity supply to people who do not yet have access to it;



WHEREAS, taking into consideration the technical challenges and time requirements for installation of FGD and other technologies to meet the new emission limits, the MoEF&CC vide its letter F. No. Q-15017/40/2007-CPW dated 07.12.2017 has directed CPCB to direct all the thermal power plants to ensure compliance with the norms laid down in the 07.12.2015 notification in accordance with the revised Plan submitted by the Ministry of Power letter dated 13.10.2017 as well as NOx by 2022;

WHEREAS, the Ministry of Environment, Forest & Climate Change, Government of India, vide Notifications No. S. O. 157 (E) of 27.02.1996 and S. O. 730 (E) dated 10.07.2002, has delegated the powers vested under Section 5 of the Environment (Protection) Act, 1986 (29 of 1986) to the Chairman, Central Pollution Control Board, to issue directions to any industry or any local body or any other authority for violations of the standards and rules notified under the Environment (Protection) Rules, 1986 and amendment thereof.

NOW, THEREFORE, taking into consideration all material facts including environmental concerns and ensuring stability of power supply and need for phasing the implementation, in exercise of powers vested under Section 5 of the Environment (Protection) Act, 1986, following directions are issued to M/s JSW Energy Limited (Extn TPS):

- i. That plant shall retrofit/ install Electrostatic Precipitator (ESP) by June 30, 2022 and September 30, 2022 in Unit 1 & 2 respectively so as to comply with PM emission limit.
- ii. That plant shall install FGD by June 30, 2022 and September 30, 2022 in Unit 1 & 2 respectively so as to comply SO<sub>2</sub> emission limit
- iii. That plant shall take immediate measure like installation of low NOx burners, providing Over Fire Air (OFA) etc. and achieve progressive reduction so as to comply NOx emission limit by the year 2022

The time line mentioned above (i to iii) for compliance of PM, SO<sub>2</sub> & NOx emission limits shall be reviewed by CPCB within a period of three months and shall be brought down further considering the location specificity of the plant such as critical polluted area/ closeness to habitation/ urban area.

The time line for compliance of water consumption limit shall also be finalised in consultation of plants

M/s JSW Energy Limited (Extn TPS) shall ensure compliance of directions mentioned above (i to iii) failing which action will be taken under the appropriate provisions of the Environment (Protection) Act, 1986.


  
(A.K. Mehta)  
Chairman

leg



Copy to:

1. The Chairman  
Karnataka State Pollution Control Board  
"Parisara Bhavan", #49, 4th & 5th Floor,  
Church Street, Bangalore 560 001
2. The Joint Secretary (CP Division)  
Ministry of Environment, Forests and Climate Change  
Prithvi Wing, 2nd Floor, Room No. 216  
Indira Paryavaran Bhawan, Aliganj,  
Jor Bagh Road, New Delhi - 110003
3. The Joint Secretary (Thermal)  
Ministry of Power  
Shram Shakti Bhawan, Rafi Marg  
New Delhi
4. The Regional Director,  
Central Pollution Control Board  
1st & 2nd Floors, Nisarga Bhavan, A-Block,  
Thimmaiah Main Road, 7th D Cross,  
Shivanagar, Bengaluru -560 079
5. The Divisional Head - IT, CPCB



(A. Sudhakar)  
Member Secretary

SPEED POST

B-33014/07/2017-18/IPC-II/TPP/

December 11, 2017

To

Kudgi Super Thermal Power Project,  
NTPC Ltd, Golasangi, Post Kudgi,  
Basavana Bagewadi Taluk  
DIST: Bijapur - 586 121, Karnataka

Sub: Directions under Section 5 of the Environment (Protection) Act, 1986 regarding compliance of emission limit notified vide notification No.S.O.3305 (E) dated 07.12.2015 - reg.

WHEREAS, taking into consideration pollution from thermal power plants, Ministry of Environment, Forest & Climate Change had issued notification in the year 1984 laying out standards for thermal power plants. Further, the stack height regulation was notified in the year 1989 and effluent standard for thermal power plants was notified in the year 1986. The revised temperature limit of discharge of cooling water from the plants was notified in the year 1999 and thereafter use of beneficiated coal in the plants was issued in June 2002. The fly ash utilization notification was also issued On 14th September, 1999 and amended in the year 2003 and 2009. Thereafter, MoEF&CC vide Notification No. S.O.3305(E) dated 07.12.2015 has amended emission limit for particulate matter and notified new limits for Sulphur dioxide (SO<sub>2</sub>), Oxides of Nitrogen (NO<sub>x</sub>) and mercury emission, and water consumption limit for coal/lignite based thermal power plants. As per the notification dated 07.12.2015, thermal power plants are required to achieve the notified limit within two years from the date of the notification i.e. by 07.12.2017;

WHEREAS, with the implementation of the amendment dated 07.12.2015, it is expected that there would be reduction in emission of PM, Sulphur dioxide and oxide of Nitrogen, which in turn will help in improvement in Ambient Air Quality in and around thermal power plants, besides reduction of mercury emission and water use in the thermal power plants will reduce;

WHEREAS, in the meeting on Coal Washeries (Environment & Forest Clearances) and Emission Norms for Thermal Power Plants chaired by the Hon'ble Minister of Environment, Forest & Climate Change and Minister of Power, Coal & Renewable Energy on June 08, 2016, it was decided that a committee comprising representatives from MoEF & CC, Ministry of Power (MoP), Central electricity Authority (CEA), Ministry of Coal (MoC), Power Grid Corporation of India Limited (PGCI) and Central Pollution Control Board (CPCB) may be constituted to look into the all issues related to implementation of norms;

WHEREAS, following decisions were taken in the meeting:

1. MoP/CEA shall submit action plan by December 2016 for phasing out of the power plants commissioned before December, 2003.
2. MoP / CEA shall submit action plan by December, 2016 in respect of power plants commissioned during January, 2004 to December, 2016 indicating unitwise retrofit / renovation for each power plant. The implementation of action plan shall be taken up in backward manner starting from the plants commissioned in the 2015 and the shall be completed by 15.08.2022
3. MoP and CEA shall coordinate with each State Public Sector Undertakings separately for submission of action plan by December, 2016 for all the power plants.

WHEREAS, it was further decided that MoP shall take action for installation of Flue gas Desulphurisation (FGD) if needed to achieve prescribed SO<sub>2</sub> norms based on the SO<sub>2</sub> emission levels from power plants;

WHEREAS, it was also pointed out that NO<sub>x</sub> control technology in case of Indian coal is not established. Selective Catalytic Reduction (SCR) technology is used for NO<sub>x</sub> control, however, its feasibility for Indian coal needs to be established. MoP suggested that Pilot studies may be taken up in two plants and based on the results, further action plan to be drawn regarding retrofitting of SCR in plants to achieve prescribed NO<sub>x</sub> norms;

WHEREAS, the MoP constituted a committee under the Chairmanship of Chairman, Central Electricity Authority (CEA) on 21.09.2016 to prepare an action plan for implementation of new emission limits;

WHEREAS, to ensure compliance of the new emission norms the MOEF&CC convened a meeting on 23.05.2017 in which CEA, NTPC and the Central Pollution Control Board participated;

WHEREAS, the MOEF&CC received a letter from Secretary Ministry of Power *vide* their D.O. letter No. FU-1/2016-IPC dated 30<sup>th</sup> June, 2017 indicating the concerns of various thermal power plants in the country with regard to the compliance with the new emission norms for the thermal power plants notified on 7.12.2015 particularly w.r.t. Particulate Matter (PM), Sulphur dioxide (SO<sub>2</sub>) & Oxides of Nitrogen (NO<sub>x</sub>);

WHEREAS, it was noted that out of present 196667 MW installed capacity, about 60 % capacity (1,15,214 MW) meets the new PM norms with existing ESP-installations. Remaining capacity of 64,334 MW which does not meet the new environmental norms regarding PM, requiring retrofitting additional fields in Electrostatic Precipitator (ESP)/replacement of ESP in existing plants to meet the new emission norms of PM;

WHEREAS, Ministry of Power after consultation with Central electricity Authority informed that retrofitting additional fields in ESP/replacement of ESP in existing plants will need complete shutdown of 4-6 months for each unit;

WHEREAS, in order to meet SO<sub>2</sub> emission norms, FGD system shall be required to be installed in all plants. MoP informed that about 30-36 months required for design&engineering, approvals, funds arrangements, tendering, erection and commissioning of FGD. Besides, planned shutdown will be required as all plants cannot be shut down simultaneously. Another challenge highlighted for installation of FGD was availability of technologies/suppliers. In addition, issues relating to availability of good quality lime stone for operation of FGD and disposal of Gypsum to run the FGD in existing plants were also taken note of;

WHEREAS, the standard of 300 & 100 mg/NM<sup>3</sup> would require installation of Selective Non Catalytic Reduction (SNCR) or Selective Non Catalytic Reduction (SCR). While these technologies are established globally, these are not established for Indian Coal, which has high ash content. Therefore, it was decided to engage various technology vendors to run pilots at NTPC stations to validate technology of SNCR/SCR system for Indian coal;

WHEREAS, the Ministry of Power in the letter dated 30.06.2017 enclosed the report outlining the plan of action for implementation of the new norms keeping in mind the techno-economic feasibility and ensuring availability of power to all at affordable cost without any disruption;

WHEREAS, as per the phasing plan proposed by MOP after consultation with CEA and Regional Power Committees, out of the installed capacity of 1, 87,162 MW ( as on December, 2016), 8217 MW have been identified for retirement/already retired. Further, 12,974 MW of capacity already have either CFBC boilers or FGDs.

WHEREAS, a phasing plan was proposed for the balance 165971 MW of coal based thermal capacity for achieving compliance with 145977 MW capacity proposing installation of FGDs within a period of 7 years to be undertaken in a phased manner. About 3205 MW of coal based capacity was stated to be compliant with revised norms of SO<sub>2</sub> emission;

WHEREAS, it was further noted that approximately about 16789 MW would not be able to install FGDs due to various constraints which include lack of space, etc.;

WHEREAS, CEA has worked out the requirement of capacity of coal based thermal power plants including hydro, wind, solar, gas based units to meet the estimated peak demand of 225 GW in 2021-22;

WHEREAS, MoP suggested that the compliance period of PM for the plants installing FGD may be kept same as per the FGD phasing plan;

WHEREAS, it was requested that for implementation of NO<sub>x</sub> norms in the plants installed before 31.12.2003 a period of three years may be permitted to achieve specified standards of 600 mg/Nm<sup>3</sup>. For other plants a relaxation

of 600 mg/Nm<sup>3</sup> in place of 300 and 100 mg/Nm<sup>3</sup> for a period of 3 years was also requested;

WHEREAS, taking into account the issues/concerns raised by the MoP and the sensitivity involved in the matter as it relates to general public of the country, the Ministry undertook detailed analysis of each of the issues in the meetings held on 06.07.2017, 27.07.2017, 11.08.2017 and 01.09.2017. These meetings were also attended by the various stakeholders including Ministry of Power, CEA, NTPC etc.;

WHEREAS, MOEF & CC in the meeting with MoP, CEA, NTPC & CPCB etc. held on September 1, 2017 decided that the action plan submitted by MoP for 7 years i.e. upto 2024 was too long and it should instead commence from 2018 and implemented by 2022 with respect to all pollutants. It was further suggested that action plan should be revised prioritising the plants located in critically polluted area /close to habitation /urban area. Based on the decisions taken in the meeting Ministry of Power vide letter No. FU-1/2017-IPC dated 13.10.2017 submitted the revised action plan, to implement/phasing FGD installation/ ESP upgradation to meet new emission norms for thermal power plants;

WHEREAS, as per the revised plan submitted by the MoP vide letter dated 13.10.2017, 650 units comprising 196667 MW need to meet the new emission limits. Out of 650 units, FGD will be installed to achieve the emission limit of SO<sub>2</sub> by the year 2022 in all 415 units comprising 161522 MW (01 unit by 2018, 08 units by 2019, and 55 units by 2020, 172 units by 2021 and 178 units by 2022, for 01 units with 150 MW capacity plan is not received). Remaining 235 units comprised of 35145 MW either complying with SO<sub>2</sub> emission limits or planned for phasing out;

WHEREAS, ESP upgradation to achieve emission limit of particulate matter will be completed by the year 2022 in PM for 231 units comprising of 65925 MW capacity out of 650 units (01 unit by 2018, 02 units by 2019, 28 units by 2020, 97 units by 2021 and 94 units by 2022, for 09 units of 1400 MW capacity plan by 2022);

WHEREAS, with regard to compliance of emission limit of NO<sub>x</sub>, it is suggested that pre combustion modification such as in situ modification in boiler, installation of Low NO<sub>x</sub> burners and Over Fire Air shall be adopted besides installation of SCR/SNCR systems wherever needed by the year 2022;

WHEREAS, electricity is cleanest form of energy which helps in mitigating house hold air pollution which is matter of concern;

WHEREAS, there is need to provide electricity supply to people who do not yet have access to it;

WHEREAS, taking into consideration the technical challenges and time requirements for installation of FGD and other technologies to meet the new emission limits, the MoEF&CC vide its letter F. No. Q-15017/40/2007-



CPWdated 07.12.2017 has directed CPCB to direct all the thermal power plants to ensure compliance with the norms laid down in the 07.12.2015 notification in accordance with the revised Plan submitted by the Ministry of Power letter dated 13.10.2017 as well as NOx by 2022;

WHEREAS, the Ministry of Environment, Forest & Climate Change, Government of India, vide Notifications No. S. O. 157 (E) of 27.02.1996 and S. O. 730 (E) dated 10.07.2002, has delegated the powers vested under Section 5 of the Environment (Protection) Act, 1986 (29 of 1986) to the Chairman, Central Pollution Control Board, to issue directions to any industry or any local body or any other authority for violations of the standards and rules notified under the Environment (Protection) Rules, 1986 and amendment thereof.

NOW, THEREFORE, taking into consideration all material facts including environmental concerns and ensuring stability of power supply and need for phasing the implementation, in exercise of powers vested under Section 5 of the Environment (Protection) Act, 1986, following directions are issued to M/s Kudgi Super Thermal Power Project:

- i. That plant shall meet emission limit of PM by installing Electrostatic Precipitator (ESP) by September 30, 2022 and December 31, 2022 in Unit 2 & 3 respectively
- ii. That plant shall install FGD by June 30, 2022, September 30, 2022 and December 31, 2022 in Unit 1, 2 & 3 respectively so as to comply SO<sub>2</sub> emission limit
- iii. That plant shall take immediate measure like installation of low NOx burners, providing Over Fire Air (OFA) etc. and achieve progressive reduction so as to comply NOx emission limit by the year 2022

The time line mentioned above (i to iii) for compliance of PM, SO<sub>2</sub> & NOx emission limits shall be reviewed by CPCB within a period of three months and shall be brought down further considering the location specificity of the plant such as critical polluted area/ closeness to habitation/ urban area.

The time line for compliance of water consumption limit shall also be finalised in consultation of plants


M/s Kudgi Super Thermal Power Project shall ensure compliance of directions mentioned above (i to iii) failing which action will be taken under the appropriate provisions of the Environment (Protection) Act, 1986.

  
(A.K. Mehta)  
Chairman

Copy to:

1. The Chairman  
Karnataka State Pollution Control Board  
"Parisara Bhavan", #49, 4th & 5th Floor,  
Church Street, Bangalore 560 001

2. The Joint Secretary (CP Division)  
Ministry of Environment, Forests and Climate Change  
Prithvi Wing, 2nd Floor, Room No. 216  
Indira Paryavaran Bhawan, Aliganj,  
Jor Bagh Road, New Delhi - 110 003
3. The Joint Secretary (Thermal)  
Ministry of Power  
Shram Shakti Bhawan, Rafi Marg  
New Delhi
4. The Regional Director,  
Central Pollution Control Board  
1st & 2nd Floors, Nisarga Bhavan, A-Block,  
Thimmaiah Main Road, 7th D Cross,  
Shivanagar, Bengaluru -560 079
- ✓ 5. The Divisional Head - IT, CPCB

  
(A. Sudhakar)  
Member Secretary

SPEED POST

B-33014/07/2017-18/IPC-II/TPP/

December 11, 2017

To

Jhabua Power Station  
Barela and Gorakhpur Villages,  
Dist. Seoni, Madhya Pradesh

Sub: Directions under Section 5 of the Environment (Protection) Act, 1986 regarding compliance of emission limit notified vide notification No.S.O.3305 (E) dated 07.12.2015 - reg.

WHEREAS, taking into consideration pollution from thermal power plants, Ministry of Environment, Forest & Climate Change had issued notification in the year 1984 laying out standards for thermal power plants. Further, the stack height regulation was notified in the year 1989 and effluent standard for thermal power plants was notified in the year 1986. The revised temperature limit of discharge of cooling water from the plants was notified in the year 1999 and thereafter use of beneficiated coal in the plants was issued in June 2002. The fly ash utilization notification was also issued on 14th September, 1999 and amended in the year 2003 and 2009. Thereafter, MoEF&CC vide Notification No. S.O.3305(E) dated 07.12.2015 has amended emission limit for particulate matter and notified new limits for Sulphur dioxide (SO<sub>2</sub>), Oxides of Nitrogen (NO<sub>x</sub>) and mercury emission, and water consumption limit for coal/lignite based thermal power plants. As per the notification dated 07.12.2015, thermal power plants are required to achieve the notified limit within two years from the date of the notification i.e. by 07.12.2017;

WHEREAS, with the implementation of the amendment dated 07.12.2015, it is expected that there would be reduction in emission of PM, Sulphur dioxide and oxide of Nitrogen, which in turn will help in improvement in Ambient Air Quality in and around thermal power plants, besides reduction of mercury emission and water use in the thermal power plants will reduce;

WHEREAS, in the meeting on Coal Washeries (Environment & Forest Clearances) and Emission Norms for Thermal Power Plants chaired by the Hon'ble Minister of Environment, Forest & Climate Change and Minister of Power, Coal & Renewable Energy on June 08, 2016, it was decided that a committee comprising representatives from MoEF & CC, Ministry of Power (MoP), Central electricity Authority (CEA), Ministry of Coal (MoC), Power Grid Corporation of India Limited (PGCI) and Central Pollution Control Board (CPCB) may be constituted to look into the all issues related to implementation of norms;

WHEREAS, following decisions were taken in the meeting:

1. MoP/CEA shall submit action plan by December 2016 for phasing out of the power plants commissioned before December, 2003.
2. MoP / CEA shall submit action plan by December, 2016 in respect of power plants commissioned during January, 2004 to December, 2016 indicating unitwise retrofit / renovation for each power plant. The implementation of action plan shall be taken up in backward manner starting from the plants commissioned in the 2015 and the shall be completed by 15.08.2022
3. MoP and CEA shall coordinate with each State Public Sector Undertakings separately for submission of action plan by December, 2016 for all the power plants.

WHEREAS, it was further decided that MoP shall take action for installation of Flue gas Desulphurisation (FGD) if needed to achieve prescribed SO<sub>2</sub> norms based on the SO<sub>2</sub> emission levels from power plants;

WHEREAS, it was also pointed out that NO<sub>x</sub> control technology in case of Indian coal is not established. Selective Catalytic Reduction (SCR) technology is used for NO<sub>x</sub> control, however, its feasibility for Indian coal needs to be established. MoP suggested that Pilot studies may be taken up in two plants and based on the results, further action plan to be drawn regarding retrofitting of SCR in plants to achieve prescribed NO<sub>x</sub> norms;

WHEREAS, the MoP constituted a committee under the Chairmanship of Chairman, Central Electricity Authority (CEA) on 21.09.2016 to prepare an action plan for implementation of new emission limits;

WHEREAS, to ensure compliance of the new emission norms the MOEF&CC convened a meeting on 23.05.2017 in which CEA, NTPC and the Central Pollution Control Board participated;

WHEREAS, the MOEF&CC received a letter from Secretary Ministry of Power *vide* their D.O. letter No. FU-1/2016-IPC dated 30<sup>th</sup> June, 2017 indicating the concerns of various thermal power plants in the country with regard to the compliance with the new emission norms for the thermal power plants notified on 7.12.2015 particularly w.r.t. Particulate Matter (PM), Sulphur dioxide (SO<sub>2</sub>) & Oxides of Nitrogen (NO<sub>x</sub>);

WHEREAS, it was noted that out of present 196667 MW installed capacity, about 60 % capacity (1,15,214 MW) meets the new PM norms with existing ESP installations. Remaining capacity of 64,334 MW which does not meet the new environmental norms regarding PM, requiring retrofitting additional fields in Electrostatic Precipitator (ESP)/replacement of ESP in existing plants to meet the new emission norms of PM;

WHEREAS, Ministry of Power after consultation with Central electricity Authority informed that retrofitting additional fields in ESP/replacement of ESP in existing plants will need complete shutdown of 4-6 months for each unit;

WHEREAS, in order to meet SO<sub>2</sub> emission norms, FGD system shall be required to be installed in all plants. MoP informed that about 30-36 months required for design&engineering, approvals, funds arrangements, tendering, erection and commissioning of FGD. Besides, planned shutdown will be required as all plants cannot be shut down simultaneously. Another challenge highlighted for installation of FGD was availability of technologies/suppliers. In addition, issues relating to availability of good quality lime stone for operation of FGD and disposal of Gypsum to run the FGD in existing plants were also taken note of;

WHEREAS, the standard of 300 & 100 mg/NM<sup>3</sup> would require installation of Selective Non Catalytic Reduction (SNCR) or Selective Non Catalytic Reduction (SCR). While these technologies are established globally, these are not established for Indian Coal, which has high ash content. Therefore, it was decided to engage various technology vendors to run pilots at NTPC stations to validate technology of SNCR/SCR system for Indian coal;

WHEREAS, the Ministry of Power in the letter dated 30.06.2017 enclosed the report outlining the plan of action for implementation of the new norms keeping in mind the techno-economic feasibility and ensuring availability of power to all at affordable cost without any disruption;

WHEREAS, as per the phasing plan proposed by MOP after consultation with CEA and Regional Power Committees, out of the installed capacity of 1, 87,162 MW ( as on December, 2016), 8217 MW have been identified for retirement/already retired. Further, 12,974 MW of capacity already have either CFBC boilers or FGDs.

WHEREAS, a phasing plan was proposed for the balance 165971 MW of coal based thermal capacity for achieving compliance with 145977 MW capacity proposing installation of FGDs within a period of 7 years to be undertaken in a phased manner. About 3205 MW of coal based capacity was stated to be compliant with revised norms of SO<sub>2</sub> emission;

WHEREAS, it was further noted that approximately about 16789 MW would not be able to install FGDs due to various constraints which include lack of space, etc.;

WHEREAS, CEA has worked out the requirement of capacity of coal based thermal power plants including hydro, wind, solar, gas based units to meet the estimated peak demand of 225 GW in 2021-22;

WHEREAS, MoP suggested that the compliance period of PM for the plants installing FGD may be kept same as per the FGD phasing plan;

WHEREAS, it was requested that for implementation of NO<sub>x</sub> norms in the plants installed before 31.12.2003 a period of three years may be permitted to achieve specified standards of 600 mg/Nm<sup>3</sup>. For other plants a relaxation



of 600 mg/Nm<sup>3</sup> in place of 300 and 100 mg/Nm<sup>3</sup> for a period of 3 years was also requested;

WHEREAS, taking into account the issues/concerns raised by the MoP and the sensitivity involved in the matter as it relates to general public of the country, the Ministry undertook detailed analysis of each of the issues in the meetings held on 06.07.2017, 27.07.2017, 11.08.2017 and 01.09.2017. These meetings were also attended by the various stakeholders including Ministry of Power, CEA, NTPC etc.;

WHEREAS, MOEF & CC in the meeting with MoP, CEA, NTPC & CPCB etc. held on September 1, 2017 decided that the action plan submitted by MoP for 7 years i.e. upto 2024 was too long and it should instead commence from 2018 and implemented by 2022 with respect to all pollutants. It was further suggested that action plan should be revised prioritising the plants located in critically polluted area /close to habitation /urban area. Based on the decisions taken in the meeting Ministry of Power vide letter No. FU-1/2017-IPC dated 13.10.2017 submitted the revised action plan, to implement/phasing FGD installation/ ESP upgradation to meet new emission norms for thermal power plants;

WHEREAS, as per the revised plan submitted by the MoP vide letter dated 13.10.2017, 650 units comprising 196667 MW need to meet the new emission limits. Out of 650 units, FGD will be installed to achieve the emission limit of SO<sub>2</sub> by the year 2022 in all 415 units comprising 161522 MW (01 unit by 2018, 08 units by 2019, and 55 units by 2020, 172 units by 2021 and 178 units by 2022, for 01 units with 150 MW capacity plan is not received). Remaining 235 units comprised of 35145 MW either complying with SO<sub>2</sub> emission limits or planned for phasing out;

WHEREAS, ESP upgradation to achieve emission limit of particulate matter will be completed by the year 2022 in PM for 231 units comprising of 65925 MW capacity out of 650 units (01 unit by 2018, 02 units by 2019, 28 units by 2020, 97 units by 2021 and 94 units by 2022, for 09 units of 1400 MW capacity plan by 2022);

WHEREAS, with regard to compliance of emission limit of NO<sub>x</sub>, it is suggested that pre combustion modification such as in situ modification in boiler, installation of Low NO<sub>x</sub> burners and Over Fire Air shall be adopted besides installation of SCR/SNCR systems wherever needed by the year 2022;

WHEREAS, electricity is cleanest form of energy which helps in mitigating house hold air pollution which is matter of concern;

WHEREAS, there is need to provide electricity supply to people who do not yet have access to it;

WHEREAS, taking into consideration the technical challenges and time requirements for installation of FGD and other technologies to meet the new emission limits, the MoEF&CC vide its letter F. No. Q-15017/40/2007-

CPWdated 07.12.2017 has directed CPCB to direct all the thermal power plants to ensure compliance with the norms laid down in the 07.12.2015 notification in accordance with the revised Plan submitted by the Ministry of Power letter dated 13.10.2017as well as NOx by 2022;

WHEREAS, the Ministry of Environment, Forest& Climate Change , Government of India, vide Notifications No. S. O. 157 (E) of 27.02.1996 and S. O. 730 (E) dated 10.07.2002, has delegated the powers vested under Section 5 of the Environment (Protection) Act, 1986 (29 of 1986) to the Chairman, Central Pollution Control Board, to issue directions to any industry or any local body or any other authority for violations of the standards and rules notified under the Environment (Protection) Rules, 1986 and amendment thereof.



NOW, THEREFORE, taking into consideration all material facts including environmental concerns and ensuring stability of power supply and need for phasing the implementation, in exercise of powers vested under Section 5 of the Environment (Protection) Act, 1986, following directions are issued to M/s Jhabua Power Station:

- i. That plant shall meet emission limit of PM immediately by installing Electrostatic Precipitator (ESP)
- ii. That plant shall install FGD by March 31, 2020 in Unit 1 so as to comply SO<sub>2</sub> emission limit
- iii. That plant shall take immediate measure like installation of low NOx burners, providing Over Fire Air ( OFA) etc.and achieve progressive reduction so as to comply NOx emission limitby the year 2022

The time line mentioned above (i to iii) for compliance of PM, SO<sub>2</sub> & NOx emission limits shall be reviewed by CPCB within a period of three months and shall be brought down further considering the location specificity of the plant such as critical polluted area/ closeness to habitation/ urban area.

The time line for compliance of water consumption limit shall also be finalised in consultation of plants


M/s Jhabua Power Station shall ensure compliance of directions mentioned above (i to iii) failing which action will be taken under the appropriate provisions of the Environment (Protection) Act, 1986.

  
(A.K. Mehta)  
Chairman  


Copy to:

1. The Chairman  
Madhya Pradesh Pollution Control Board  
Paryavaran Parisar, E-5, Arera Colony  
Bhopal 462 016, Madhya Pradesh

2. The Joint Secretary (CP Division)  
Ministry of Environment, Forests and Climate Change  
Prithvi Wing, 2nd Floor, Room No. 216  
Indira Paryavaran Bhawan, Aliganj,  
Jor Bagh Road, New Delhi - 110 003
3. The Joint Secretary (Thermal)  
Ministry of Power  
Shram Shakti Bhawan, Rafi Marg  
New Delhi
4. The Regional Director,  
Central Pollution Control Board  
4th Floor, Sahkar Bhawan, North TT Nagar,  
Bhopal - 462 003
- ✓ 5. The Divisional Head - IT, CPCB

  
(A. Sudhakar)  
Member Secretary